

# Bharatpur Water Supply Management Board

Bharatpur, Chitwan

## Drinking Water Quality Test Report of Different Randomly Selected Customers (Mangsir)

S.N	Name of Source			Date ↓	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (μS/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)	Remarks
	Customer Name	Customer ID	Area No	Max. Concentration Limits, as per Nepal Drinking Water Quality Standards →	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0	
1	Puspa Raj Sapkota	1380	10-1A	2070-08-13	1	7.7	5	NO	324	Neg.	0	
2	Iman Bahadur Gurung	2905	2-01	"	1	7.4	5	NO	240	Neg.	0	
3	Matlab Miya	3325	11-23	"	2	7.0	5	NO	253	Neg.	0	
4	Shalik Ram Paudel	12700	12-19	"	2	7.8	5	NO	260	Neg.	0	
5	Radha Devi Khanal	4705	7-10	2070-08-14	1	7.0	5	NO	272	Neg.	35	
	"	4705	7-10	2070-08-16							0	After Correction
6	Krishna Prasad Risal	8195	7-20	2070-08-14	1	7.1	5	NO	261	Neg.	0	
7	Yamuna Prasad Adhikari	9295	7-20	"	3	7.2	5	NO	330	Neg.	0	
8	Bhagawati Padhya	9305	7-12	"	1	6.9	5	NO	273	Neg.	0	
9	Bharatpur W.N. 12 Office	12925	12-19	2070-08-16	1	8.0	5	NO	287	Neg.	0	
10	Bed Maya giri	13210	10-6A	"	1	7.7	5	NO	380	Neg.	0	
11	Sumitra Rana	14200	9-08	"	1	7.9	5	NO	297	Neg.	0	
12	Churna Dutta Suvedi	11930	9-17	"	1	7.7	5	NO	420	Neg.	0	
13	Mina Kumari Paudel	13810	14-25	2070-08-17	1	8.2	5	NO	198	Neg.	0	
14	Goma Thapa Chhetri	13165	14-25	"	2	8.2	5	NO	198	Neg.	0	
15	Jaya Prasad Sapkota	14255	6-19	"	1	8.1	5	NO	266	Neg.	0	
16	Khem Lal Suvedi	11565	6-18	"	1	8.2	5	NO	267	Neg.	0	
17	Nabaraj Dhakal	1859	2-15	2070-08-19	1	7.1	5	NO	158	Neg.	0	
18	Bhim Maya Tamang	6393	2-23	"	1	6.6	5	NO	130	Neg.	0	

# Bharatpur Water Supply Management Board

Bharatpur, Chitwan

## Drinking Water Quality Test Report of Different Randomly Selected Customers (Mangsir)

S.N	Name of Source			Date ↓	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (μS/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)	Remarks
	Customer Name	Customer ID	Area No	Max. Concentration Limits, as per Nepal Drinking Water Quality Standards →	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0	
19	Rajendra Bahadur Bhandari	1495	10-29	"	1	7.7	5	NO	217	Neg.	0	
20	Chandra Mitra Pandit	14850	4-1	"	2	7.9	5	NO	300	Neg.	0	
21	Krishna Kumari Panta	4680	12-16	2070-08-20	1	7.7	5	NO	214	Neg.	0	
22	Gadesh Paudel	4170	10-12	"	2	7.4	5	NO	384	Neg.	0	
23	Gopal Prasad Kandel	5800	8-12	"	3	7.9	5	NO	210	Neg.	0	
24	Toya Nath Bhattarai	3153	10-30	"	1	7.9	5	NO	212	Neg.	0	
25	Diwakar Lamichane	10770	10-2	"	1	7.9	5	NO	214	Neg.	0	
26	Bhakti Ram Gautam	390	3-4	2070-08-21	2	7.9	5	NO	294	Neg.	0	
27	Jagannath Kandel	12404	4-10	"	3	7.8	5	NO	382	Neg.	0	
28	Bhagbati Paudel	13893	4-3	"	2	7.7	5	NO	373	Neg.	0	
29	Sita Kumari Paudel	8480	5-9	"	3	8.0	5	NO	256	Neg.	0	
30	Hari Dash Sapkota	8810	6-18	"	2	8.0	5	NO	255	Neg.	0	

\* These values show lower and Upper Limits

( ) Values refers acceptable values only when no alternative available

( Ram Krishna Khanal )

Tested By:

(Shalik Ram Paudel)

Approved By: