

Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Different Randomly Selected Customers (Paush)

S.N	Name of Source			Date ↓	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (μS/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)	Remarks
	Customer Name	Customer ID	Area No	Max. Concentration Limits, as per Nepal Drinking Water Quality Standards →	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0	
1	Iman Bahadur Gurung	2905	2-01	2070-9-16	3	7.7	5	NO	269	0.05	0	
2	Nabaraj Dhakal	1859	2-15	2070-9-16	4	7.6	5	NO	277	0.05	0	
3	Bhim Maya Tamang	6393	2-23	2070-9-16	4	6.6	5	NO	166	0.06	0	
4	Bhakti Ram Gautam	390	3-04	2070-9-16	5	7.8	5	NO	274	0.05	0	
5	Bhagbati Paudel	13893	4-03	2070-9-16	4	7.8	5	NO	371	0.07	0	
6	Chandra Mitra Pandit	14850	4-01	2070-9-16	5	7.8	5	NO	384	0.05	0	
7	Jagannath Kandel	12404	4-10	2070-9-16	2	8.0	5	NO	371	0.05	0	
8	Sita Kumari Paudel	8480	5-09	2070-9-16	4	8.2	5	NO	383	0.08	0	
9	Hari Dash Sapkota	8810	6-18	2070-9-24	1	8.3	5	NO	252	0.05	0	
10	Khem Lal Suvedi	11565	6-18	2070-9-24	3	8.4	5	NO	241	0.05	0	
11	Jaya Prasad Sapkota	14255	6-19	2070-9-24	1	8.4	5	NO	246	0.09	0	
12	Radha Devi Khanal	4705	7-10	2070-9-24	1	7.8	5	NO	254	0.05	0	
13	Bhagawati Padhya	9305	7-12	2070-9-24	1	8.2	5	NO	255	0.06	0	
14	Krishna Prasad Risal	8195	7-20	2070-9-24	2	8.0	5	NO	245	0.05	0	
15	Yamuna Prasad Adhikari	9295	7-20	2070-9-24	1	7.8	5	NO	243	0.07	0	
16	Gopal Prasad Kandel	5800	8-12	2070-9-24	1	7.9	5	NO	255	0.05	0	
17	Sumitra Rana	14200	9-08	2070-9-24	2	8.1	5	NO	272	0.06	0	
18	Churna Dutta Suvedi	11930	9-17	2070-9-24	1	7.9	5	NO	287	0.05	0	
19	Puspa Raj Sapkota	1380	10-1A	2070-9-14	1	7.5	5	NO	254	0.07	0	
20	Diwakar Lamichane	10770	10-02	2070-9-14	1	7.8	5	NO	391	0.05	3	
21	Bed Maya giri	13210	10-6A	2070-9-14	1	7.8	5	NO	327	0.05	0	

Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Different Randomly Selected Customers (Paush)

S.N	Name of Source			Date ↓	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (μS/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)	Remarks
	Customer Name	Customer ID	Area No	Max. Concentration Limits, as per Nepal Drinking Water Quality Standards →	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0	
22	Gadesh Paudel	4170	10-12	2070-9-14	1	7.9	5	NO	276	0.09	0	
23	Rajendra Bahadur Bhandari	1495	10-29	2070-9-14	2	8.0	5	NO	270	0.05	0	
24	Toya Nath Bhattarai	3153	10-30	2070-9-14	2	7.0	5	NO	688	0.06	0	
25	Matlab Miya	3325	11-23	2070-9-14	2	7.9	5	NO	273	0.05	0	
26	Shalik Ram Paudel	12700	12-19	2070-9-14	2	7.8	5	NO	270	0.08	0	
27	Krishna Kumari Panta	4680	12-16	2070-9-14	3	8.0	5	NO	260	0.07	0	
28	Bharatpur W.N. 12 Office	12925	12-19	2070-9-14	4	8.0	5	NO	261	0.07	5	
	"	12925	12-19	2070-9-29							0	After Correction
29	Mina Kumari Paudel	13810	14-25	2070-9-22	2	8.7	5	NO	206	0.08	0	
30	Goma Thapa Chhetri	13165	14-25	2070-9-22	2	8.6	5	NO	197	0.05	0	

* These values show lower and Upper Limits

() Values refers acceptable values only when no alternative available

(Ram Krishna Khanal)
Tested By:

(Shalik Ram Paudel)
Approved By: