

Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Different Randomly Selected Customers (Falgun)

S.N	Name of Source			Date ↓	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (μS/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)	Remarks
	Customer Name	Customer ID	Area No	Max. Concentration Limits, as per Nepal Drinking Water Quality Standards →	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0	
1	Iman Bahadur Gurung	2905	2-01	2070-11-23	1	7.7	5	NO	300	0.07	0	
2	Nabaraj Dhakal	1859	2-15	2070-11-23	1	7.8	5	NO	305	0.09	0	
3	Bhim Maya Tamang	6393	2-23	2070-11-23	1	6.5	5	NO	183	0.08	0	
4	Bhakti Ram Gautam	390	3-04	2070-11-23	2	7.9	5	NO	315	0.06	0	
5	Bhagbati Paudel	13893	4-03	2070-11-23	2	7.6	5	NO	362	0.07	0	
6	Chandra Mitra Pandit	14850	4-01	2070-11-23	2	7.6	5	NO	418	0.08	0	
7	Jagannath Kandel	12404	4-10	2070-11-23	2	7.8	5	NO	421	0.07	0	
8	Sita Kumari Paudel	8480	5-09	2070-11-23	2	7.8	5	NO	424	0.08	0	
9	Hari Dash Sapkota	8810	6-18	2070-11-26	1	7.9	5	NO	301	0.06	0	
10	Khem Lal Suvedi	11565	6-18	2070-11-26	1	8.1	5	NO	280	0.07	0	
11	Jaya Prasad Sapkota	14255	6-19	2070-11-26	1	8.0	5	NO	515	0.05	0	
12	Radha Devi Khanal	4705	7-10	2070-11-26	1	7.6	5	NO	515	0.08	0	
13	Bhagawati Padhya	9305	7-12	2070-11-26	1	8.0	5	NO	273	0.08	0	
14	Krishna Prasad Risal	8195	7-20	2070-11-26	1	7.4	5	NO	497	0.05	0	
15	Yamuna Prasad Adhikari	9295	7-20	2070-11-26	3	7.6	5	NO	275	0.06	0	
16	Gopal Prasad Kandel	5800	8-12	2070-11-27	1	8.1	5	NO	279	0.09	0	
17	Sumitra Rana	14200	9-08	2070-11-27	1	7.7	5	NO	350	0.07	0	
18	Churna Dutta Suvedi	11930	9-17	2070-11-27	1	7.7	5	NO	345	0.07	0	

Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Different Randomly Selected Customers (Falgun)

S.N	Name of Source			Date ↓	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (μS/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)	Remarks
	Customer Name	Customer ID	Area No	Max. Concentration Limits, as per Nepal Drinking Water Quality Standards →	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0	
19	Puspa Raj Sapkota	1380	10-1A	2070-11-25	1	7.7	5	NO	306	0.09	0	
20	Diwakar Lamichane	10770	10-02	2070-11-27	1	7.4	5	NO	535	0.08	0	
21	Bed Maya giri	13210	10-6A	2070-11-27	1	7.6	5	NO	363	0.07	0	
22	Gadesh Paudel	4170	10-12	2070-11-28	2	7.5	5	NO	381	0.07	0	
23	Rajendra Bahadur Bhandari	1495	10-29	2070-11-25	2	7.8	5	NO	305	0.09	0	
24	Toya Nath Bhattarai	3153	10-30	2070-11-25	1	7.8	5	NO	302	0.08	0	
25	Matlab Miya	3325	11-23	2070-11-25	1	7.7	5	NO	301	0.09	0	
26	Shalik Ram Paudel	12700	12-19	2070-11-28	1	7.9	5	NO	315	0.08	0	
27	Krishna Kumari Panta	4680	12-16	2070-11-28	1	7.9	5	NO	304	0.08	0	
28	Bharatpur W.N. 12 Office	12925	12-19	2070-11-28	1	8.3	5	NO	298	0.06	0	
29	Mina Kumari Paudel	13810	14-25	2070-11-27	2	8.1	5	NO	205	0.04	0	
30	Goma Thapa Chhetri	13165	14-25	2070-11-27	1	8.2	5	NO	280	0.05	0	

* These values show lower and Upper Limits

() Values refers acceptable values only when no alternative available

(Ram Krishna Khanal)

Tested By:

(Shalik Ram Paudel)

Approved By: