

Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Different Randomly Selected Customers (KARTIK) 2074

S.N	Name of Source			Date ↓	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (μS/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)
	Customer Name	Customer ID	Area No	Max. Concent. Limits, as per NDWOS →	°C	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0
1	Iman Bahadur Gurung	2905	2-01	7/23/2074	25	1	7.6	<5	NO	370	<0.1	0
2	Nabaraj Dhakal	1859	2-15	7/23/2074	25	1	7.4	<5	NO	580	<0.1	0
3	Bhim Maya Tamang	6393	2-23	7/23/2074	23	<2	6.2	<5	NO	227	<0.1	0
4	Bhakti Ram Gautam	390	3-04	7/23/2074	25	<2	7.9	<5	NO	348	<0.1	0
5	Bhagbati Paudel	13893	4-03	7/23/2074	23	<2	7.4	<5	NO	507	<0.1	0
6	Chandra Mitra Pandit	14850	4-01	7/23/2074	24	<1	7.6	<5	NO	486	<0.1	0
7	Jagannath Kandel	12404	4-10	7/23/2074	25	<1	7.4	<5	NO	493	<0.1	0
8	Narayan Prasad Shrestha	7740	4-01A	7/23/2074	23	<1	7.3	<5	NO	492	<0.1	0
9	Hari Dash Sapkota	8810	6-18	7/23/2074	25	<1	7.1	<5	NO	618	<0.1	0
10	Khem Lal Suvedi	11565	6-18	7/23/2074	25	<1	7.2	<5	NO	610	<0.1	0
11	Jaya Prasad Sapkota	14255	6-19	7/23/2074	23	<1	7.2	<5	NO	614	<0.1	0
12	Radha Devi Khanal	4705	7-10	7/23/2074	23	<1	7.2	<5	NO	618	<0.1	0
13	Bhagawati Padhya	9305	7-12	7/23/2074	23	<1	7.2	<5	NO	618	<0.1	0
14	Krishna Prasad Risal	8195	7-20	7/23/2074	24	<1	7.2	<5	NO	621	<0.1	0
15	Yamuna Prasad Adhikari	9295	7-20	7/28/2074	23	1	7.3	<5	NO	608	<0.1	0
16	Gopal Prasad Kandel	5800	8-12	7/28/2074	24	<1	7.3	<5	NO	335	<0.1	0
17	Sumitra Rana	14200	9-08	7/28/2074	23	<1	7.1	<5	NO	369	<0.1	0
18	Churna Dutta Suvedi	11930	9-17	7/28/2074	25	<1	7.3	<5	NO	334	<0.1	0
19	Puspa Raj Sapkota	1380	10-1A	7/28/2074	23	<1	7.6	<5	NO	352	<0.1	0
20	Diwakar Lamichane	10770	10-02	7/28/2074	24	<2	7.8	<5	NO	364	<0.1	0
21	Bed Maya giri	13210	10-6A	7/28/2074	24	<1	7.2	<5	NO	524	<0.1	0
22	Gadesh Paudel	4170	10-12	7/28/2074	23	<1	7.7	<5	NO	624	<0.1	0
23	Rajendra Bahadur Bhandari	1495	10-29	7/28/2074	24	<1	7.5	<5	NO	382	<0.1	0
24	Toya Nath Bhattarai	3153	10-30	7/28/2074	25	<2	7.5	<5	NO	381	<0.1	0

Tested By:
Ram Krishna Khanal

Checked By:
Sanjaya Baral

Approved By:
Prajapatai Dahal

S.N	Name of Source			Date ↓	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)
	Customer Name	Customer ID	Area No	Max. Concent. Limits, as per NDWOS →	° C	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0
25	Matlab Miya	3325	11-23	7/28/2074	25	<1	7.7	<5	NO	348	<0.1	0
26	Shalik Ram Paudel	12700	12-19	7/28/2074	24	<1	7.7	<5	NO	447	<0.1	0
27	Krishna Kumari Panta	4680	12-16	7/28/2074	23	<1	7.5	<5	NO	383	<0.1	0
28	Bharatpur W.N. 12 Office	12925	12-19	7/28/2074	23	<1	7.4	<5	NO	382	<0.1	0
29	Mina Kumari Paudel	13810	14-25	7/28/2074	24	<1	7.2	<5	NO	617	<0.1	0
30	Goma Thapa Chhetri	13165	14-25	7/28/2074	23	1	7.2	<5	NO	617	<0.1	0
31	Blank			7/28/2074								0
32	Contaminated Water with Cowdung			7/28/2074								>50

* These values show lower and Upper Limits

Tested By:
Ram Krishna Khanal

Checked By:
Sanjaya Baral

Approved By:
Prajapatai Dahal