



BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Water Quality Test Report of Randomly Selected Customers (BHADRA) 2077

S. N	Name of Source			Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)
	Customer Name	Customer ID	Area No	Max. Concent. Limits, as per NDWQS →	°C	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
1	Iman Bahadur Gurung	2905	2-01	29/05/2077	29.6	<1	7.9	<5	NO	370	<0.1	0
2	Nabaraj Dhakal	1859	2-15	29/05/2077	29.4	1	7.9	<5	NO	371	<0.1	0
3	Bhim Maya Tamang	6393	2-23	29/05/2077	30.2	<1	7.9	<5	NO	408	<0.1	0
4	Bhakti Ram Gautam	390	3-04	29/05/2077	29.8	<1	7.7	<5	NO	397	<0.1	0
5	Chandra Mitra Pandit	14850	4-01	29/05/2077	29.8	1	7.6	<5	NO	369	<0.1	7
6	Jagannath Kandel	12404	4-10	26/05/2077	29.8	2	7.7	<5	NO	431	<0.1	0
	Repeated Sample			29/05/2077								
7	Narayan Pd. Shrestha	7740	4-01A	29/05/2077	29.9	1	7.6	<5	NO	365	<0.1	0
8	Hari Dash Sapkota	8810	6-18	26/05/2077	29.7	1	8.0	<5	NO	389	<0.1	0
9	Khem Lal Suvedi	11565	6-18	26/05/2077	29.6	<2	7.6	<5	NO	501	<0.1	0
10	Jaya Prasad Sapkota	14255	6-19	26/05/2077	30	<2	7.5	<5	NO	340	<0.1	0
11	Radha Devi Khanal	4705	7-10	26/05/2077	29.5	<1	7.7	<5	NO	626	<0.1	0
12	Bhagawati Padhya	9305	7-12	26/05/2077	29.4	1	7.5	<5	NO	615	<0.1	0
13	Krishna Prasad Risal	8195	7-20	26/05/2077	29.4	1	7.4	<5	NO	320	<0.1	0
14	Yamuna Pd. Adhikari	9295	7-20	26/05/2077	29.3	1	7.6	<5	NO	637	<0.1	0
15	Ramakant Sharma	623	8-A2	29/05/2077	29.6	<1	7.9	<5	NO	401	<0.1	0
16	Sumitra Rana	14200	9-08	26/05/2077	29.7	<2	7.6	<5	NO	370	<0.1	0
17	Churna Dutta Suvedi	11930	9-17	26/05/2077	29.7	<2	8.0	<5	NO	375	<0.1	0
18	Puspa Raj Sapkota	1380	10-1A	29/05/2077	29.3	<1	8.0	<5	NO	373	<0.1	0
19	Diwakar Lamichane	10770	10-02	26/05/2077	29.7	<2	7.9	<5	NO	376	<0.1	0
20	Bed Maya giri	13210	10-6A	26/05/2077	30.1	<2	8.1	<5	NO	373	<0.1	0
21	Gadesh Paudel	4170	10-12	29/05/2077	30	<1	7.9	<5	NO	398	<0.1	0
22	Rajendra Bdr. Bhandari	1495	10-29	29/05/2077	30.2	<1	8.0	<5	NO	265	<0.1	0
23	Toya Nath Bhattarai	3153	10-30	29/05/2077	29.4	1	8.0	<5	NO	369	<0.1	0
24	Matlab Miya	3325	11-23	29/05/2077	29.8	<1	7.9	<5	NO	266	<0.1	0
25	Shalik Ram Paudel	12700	12-19	29/05/2077	29.9	1	7.7	<5	NO	397	<0.1	0
26	Krishna Kumari Panta	4680	12-16	29/05/2077	29.8	<1	7.9	<5	NO	408	<0.1	0
27	Bharatpur W.N. 12 Office	12925	12-19	29/05/2077	29.6	1	8.0	<5	NO	361	<0.1	0
28	Mina Kumari Paudel	13810	14-25	26/05/2077	29.5	2	7.9	<5	NO	439	<0.1	0
29	Goma Thapa Chhetri	13165	14-25	26/05/2077	29.8	<2	7.7	<5	NO	363	<0.1	0
30	Gopal Prasad Kandel	5800	12-8	26/05/2077	29.6	1	8.0	<5	NO	375	<0.1	0
31	Blank			26/05/2077								>5
32	Contaminated Water			26/05/2077								

* These values show lower and Upper Limits

Tested By: Ram Krishna Khanal

Checked By: Sanjaya Baral
Asst. Administration Officer

Approved By: Prajapati

कार्यकारी निवेष्टा