

Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Different Randomly Selected Customers (Mangsir)

S.N	Name of Source			Date	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)	Remarks
	Customer Name	Customer ID	Area No	Max. Concentration Limits, as per Nepal Drinking Water Quality Standards	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0	
1	Puspa Raj Sapkota	1380	10-1A	2070-08-13	1	7.7	5	NO	324	Neg.	0	
2	Iman Bahadur Gurung	2905	2-01	"	1	7.4	5	NO	240	Neg.	0	
3	Matlab Miya	3325	11-23	"	2	7.0	5	NO	253	Neg.	0	
4	Shalik Ram Paudel	12700	12-19	"	2	7.8	5	NO	260	Neg.	0	
5	Radha Devi Khanal	4705	7-10	2070-08-14	1	7.0	5	NO	272	Neg.	35	
	"	4705	7-10	2070-08-16							0	After Correction
6	Krishna Prasad Risal	8195	7-20	2070-08-14	1	7.1	5	NO	261	Neg.	0	
7	Yamuna Prasad Adhikari	9295	7-20	"	3	7.2	5	NO	330	Neg.	0	
8	Bhagawati Padhya	9305	7-12	"	1	6.9	5	NO	273	Neg.	0	
9	Bharatpur W.N. 12 Office	12925	12-19	2070-08-16	1	8.0	5	NO	287	Neg.	0	
10	Bed Maya giri	13210	10-6A	"	1	7.7	5	NO	380	Neg.	0	
11	Sumitra Rana	14200	9-08	"	1	7.9	5	NO	297	Neg.	0	
12	Churna Dutta Suvedi	11930	9-17	"	1	7.7	5	NO	420	Neg.	0	
13	Mina Kumari Paudel	13810	14-25	2070-08-17	1	8.2	5	NO	198	Neg.	0	
14	Goma Thapa Chhetri	13165	14-25	"	2	8.2	5	NO	198	Neg.	0	
15	Jaya Prasad Sapkota	14255	6-19	"	1	8.1	5	NO	266	Neg.	0	
16	Khem Lal Suvedi	11565	6-18	"	1	8.2	5	NO	267	Neg.	0	

* These values show lower and Upper Limits

() Values refers acceptable values only when no alternative available

Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Different Randomly Selected Customers (Mangsir)

S.N	Name of Source			Date	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Fecal Coliform (CFU/100ml)	Remarks
	Customer Name	Customer ID	Area No	Max. Concentration Limits, as per Nepal Drinking Water Quality Standards	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2*	0	
17	Nabaraj Dhakal	1859	2-15	2070-08-19	1	7.1	5	NO	158	Neg.	0	
18	Bhim Maya Tamang	6393	2-23	"	1	6.6	5	NO	130	Neg.	0	
19	Rajendra Bahadur Bhandari	1495	10-29	"	1	7.7	5	NO	217	Neg.	0	
20	Chandra Mitra Pandit	14850	4-1	"	2	7.9	5	NO	300	Neg.	0	
21	Krishna Kumari Panta	4680	12-16	2070-08-20	1	7.7	5	NO	214	Neg.	0	
22	Gadesh Paudel	4170	10-12	"	2	7.4	5	NO	384	Neg.	0	
23	Gopal Prasad Kandel	5800	8-12	"	3	7.9	5	NO	210	Neg.	0	
24	Toya Nath Bhattarai	3153	10-30	"	1	7.9	5	NO	212	Neg.	0	
25	Diwakar Lamichane	10770	10-2	"	1	7.9	5	NO	214	Neg.	0	
26	Bhakti Ram Gautam	390	3-4	2070-08-21	2	7.9	5	NO	294	Neg.	0	
27	Jagannath Kandel	12404	4-10	"	3	7.8	5	NO	382	Neg.	0	
28	Bhagbati Paudel	13893	4-3	"	2	7.7	5	NO	373	Neg.	0	
29	Sita Kumari Paudel	8480	5-9	"	3	8.0	5	NO	256	Neg.	0	
30	Hari Dash Sapkota	8810	6-18	"	2	8.0	5	NO	255	Neg.	0	

* These values show lower and Upper Limits

() Values refers acceptable values only when no alternative available