

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Uttar Pradesh

Drinking Water Quality Test Report of Randomly Selected Customers (ASHADH) 2080

S.N	Name of Source		Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
1	Iman Bahadur Gurung	2905	2-01	30.6	5(10)	6.5 to 8.5*	<5	Non objectionable	1500	0.1-0.2	0
2	Nabaraj Dhakal	1859	2-15	30.4	1	7.7	<5	NO	465	<0.1	0
3	Bhim Maya Tamang	6393	2-23	30.4	1	6.8	<5	NO	251	<0.1	0
4	Bhakti Ram Gautam	390	3-04	30.3	2	6.5	<5	NO	240	<0.1	0
5	Chandra Mitra Pandit	14850	4-01	30.1	1	7.5	<5	NO	549	<0.1	0
6	Jagannath Kandel	12404	4-10	30.4	2	7.5	<5	NO	549	<0.1	0
7	Narayan Pd. Shrestha	7740	4-01A	30.4	1	7.6	<5	NO	395	<0.1	0
8	Hari Dash Sapkota	8810	6-18	30.4	2	7.5	<5	NO	548	<0.1	0
9	Khem Lal Suvedi	11565	6-18	30.4	2	7.6	<5	NO	415	<0.1	0
10	Jaya Prasad Sapkota	14255	6-18	30.3	2	7.9	<5	NO	316	<0.1	0
11	Radha Devi Khanal	4705	7-10	30.4	1	7.7	<5	NO	382	<0.1	0
12	Bhagawati Padhya	9305	7-12	30.1	2	7.7	<5	NO	444	<0.1	0
13	Krishna Prasad Risal	8195	7-20	30.6	2	7.6	<5	NO	493	<0.1	0
14	Yamuna Pd. Adhikari	9295	7-20	30.6	1	7.6	<5	NO	395	<0.1	0
15	Ramakant Sharma	623	8-A2	30.4	1	7.6	<5	NO	392	<0.1	0
16	Sumitra Rana	14200	9-08	30.4	1	6.5	<5	NO	249	<0.1	0
17	Churna Dutta Suvedi	11930	9-17	30.7	2	7.9	<5	NO	296	<0.1	0
18	Puspa Raj Sapkota	1380	10-1A	30.1	2	7.5	<5	NO	399	<0.1	0
19	Diwakar Lamichane	10770	10-02	30.2	2	7.4	<5	NO	523	<0.1	0
20	Bed Maya giri	13210	10-6A	30.4	2	7.7	<5	NO	468	<0.1	0
21	Gadesh Paudel	4170	10-12	29.9	2	7.2	<5	NO	707	<0.1	0
22	Khim maya Baral	16688	7-16	30.5	2	7.3	<5	NO	684	<0.1	0
	Repeated sample			31.1	2	7.5	<5	NO	457	<0.1	2
23	Durga Maya Pradhan	6663	10-15	28/03/2080							0
24	Matlab Miya	3325	11-16	30.7	1	7.4	<5	NO	509	0.1	0
25	Shalik Ram Paudel	12700	12-19	30.2	1	7.6	<5	NO	466	<0.1	0
26	Hemlal Dahal	15604	10-16	30.7	2	7.6	<5	NO	479	<0.1	0
27	ward no 12 karyalaya	33210	12-5	30.6	3	7.5	<5	NO	398	<0.1	0
28	Mina Kumari Paudel	13810	14-25	30.6	2	7.8	<5	NO	256	<0.1	0
29	Goma Thapa Chhetri	13165	14-25	30.5	2	7.9	<5	NO	296	<0.1	0
30	Gopal Prasad Kandel	5800	8-12	30.3	2	7.8	<5	NO	296	<0.1	0
31	Blank			30.3	2	7.6	<5	NO	419	<0.1	0
32	Contaminated Water with Cowdung										>50

* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water

Tested By: Ram Krishna Khanal

Checked By: Sanjaya Baral

Officer

Water Administration

Executive Director

Approved By: Prajapatai Dahal