


BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (ASHWIN) 2080



Sl. No.	Name of Source		Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
		Area No	Max. Concent. Limits, as per NPDWQS-->		5 (10)	6.5 to 8.5*	5 (15)	Non objectionable	1500	0.1-0.2	0
1	Iman Bahadur Gurung	2905	21/06/2080	28.9	2	7.6	<5	NO	435	<0.1	0
2	Nabaraj Dhakal	1859	21/06/2080	28.9	2	6.7	<5	NO	258	<0.1	0
3	Bhim Maya Tamang	6393	21/06/2080	28.9	1	6.6	<5	NO	242	<0.1	0
4	Bhakti Ram Gautam	390	21/06/2080	28.5	2	7.5	<5	NO	534	<0.1	0
5	Chandra Mitra Pandit	14850	21/06/2080	28.7	2	7.5	<5	NO	533	<0.1	0
6	Jagannath Kandel	12404	26/06/2080	28.9	2	8.1	<5	NO	292	<0.1	0
7	Narayan Pd. Shrestha	7740	21/06/2080	28.8	1	7.5	<5	NO	531	<0.1	0
8	Hari Dash Sapkota	8810	26/06/2080	28.6	1	8.1	<5	NO	293	<0.1	0
9	Khem Lal Suvedi	11565	26/06/2080	28.9	1	7.8	<5	NO	295	<0.1	0
10	Jaya Prasad Sapkota	14255	26/06/2080	28.9	2	8.1	<5	NO	292	<0.1	0
11	Radha Devi Khanal	4705	26/06/2080	28.4	2	7.9	<5	NO	446	<0.1	0
12	Bhagawati Padya	9305	26/06/2080	28.6	2	8.1	<5	NO	420	<0.1	0
13	Krishna Prasad Risal	8195	26/06/2080	29.3	2	8.0	<5	NO	293	<0.1	0
14	Yamuna Pd. Adhikari	9295	26/06/2080	28.8	2	8.1	<5	NO	293	<0.1	0
15	Ramakant Sharma	623	21/06/2080	28.8	2	6.7	<5	NO	263	<0.1	0
16	Sumitra Rana	14200	26/06/2080	28.6	2	7.9	<5	NO	293	<0.1	0
17	Churna Dutta Suvedi	11930	26/06/2080	28.4	2	7.8	<5	NO	391	<0.1	0
18	Puspa Raj Sapkota	1380	21/06/2080	28.3	2	7.1	<5	NO	391	<0.1	0
19	Diwakar Lamichane	10770	26/06/2080	28.3	2	7.9	<5	NO	412	<0.1	0
20	Bed Maya giri	13210	26/06/2080	28.4	2	7.6	<5	NO	707	<0.1	2
21	Gadesh Paudel	4170	21/06/2080	28.9	2	7.2	<5	NO	555	<0.1	0
	Repeated sample		27/06/2080								
22	Khim maya Baral	16688	21/06/2080	29.1	1	7.7	<5	NO	449	<0.1	0
23	Durga Maya Pradhan	6663	21/06/2080	28.8	2	7.7	<5	NO	443	0.1	0
24	Matlab Miya	3325	21/06/2080	28.6	2	7.6	<5	NO	441	<0.1	0
25	Shalik Ram Paudel	12700	21/06/2080	29.1	2	7.5	<5	NO	482	<0.1	6
26	Hemlal Dahal	15604	21/06/2080	28.9	1	7.3	<5	NO	429	<0.1	0
	Repeated sample		27/06/2080								
27	ward no 12 karyalaya	33210	21/06/2080	29.9	2	7.8	<5	NO	257	<0.1	>30
	Repeated sample		27/06/2080								
28	Mina Kumari Paudel	13810	26/06/2080	28.2	2	8.1	<5	NO	292	<0.1	0
29	Goma Thapa Chhetri	13165	26/06/2080	28.6	1	8.0	<5	NO	286	<0.1	0
30	Gopal Prasad Kandel	5800	26/06/2080	28.8	2	7.8	<5	NO	447	<0.1	0
31	Blank		21/06/2080								
32	Contaminated Water with Cowdung		21/06/2080								>50

Tested By: Ram Krishna Khanal

Chemist

Checked By: Sanjaya Baral

Sanjaya Baral
Senior administration Officer

Executive Director
Ajaya Patal Dahal