

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (Baisakh) 2080

S.N	Name of Source		Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
		Area No	Max. Concent. Limits, as per NDWQS-->	° C	5 (10)	6.5 to 8.5*	5 (15)	Non objectionable	1500	0.1-0.2	0
1	Iman Bahadur Gurung	2-01	25/01/2080	30.6	2	7.6	<5	NO	447	<0.1	0
2	Nabaraj Dhakal	2-15	25/01/2080	31.5	1	6.6	<5	NO	258	<0.1	0
3	Bhim Maya Tamang	2-23	25/01/2080	31.9	2	6.6	<5	NO	286	<0.1	0
4	Bhakti Ram Gautam	3-04	25/01/2080	31.6	2	7.4	<5	NO	557	<0.1	0
5	Chandra Mitra Pandit	4-01	25/01/2080	30.2	2	7.4	<5	NO	559	<0.1	0
6	Jagannath Kandel	4-10	27/01/2080	31.8	1	8.0	<5	NO	297	<0.1	0
7	Narayan Pd. Shrestha	4-01A	25/01/2080	30.5	2	7.5	<5	NO	595	<0.1	>30
	Repeated sample		26/01/2080								0
8	Hari Dash Sapkota	6-18	27/01/2080	32.3	1	7.6	<5	NO	433	<0.1	0
9	Khem Lal Suvedi	6-18	27/01/2080	31.9	2	7.5	<5	NO	421	<0.1	0
10	Jaya Prasad Sapkota	6-19	27/01/2080	32.6	2	7.8	<5	NO	388	<0.1	0
11	Radha Devi Khanal	7-10	27/01/2080	31.7	2	7.2	<5	NO	700	<0.1	0
12	Bhagawati Padya	7-12	27/01/2080	31.9	1	7.7	<5	NO	446	<0.1	0
13	Krishna Prasad Risal	7-20	27/01/2080	31.6	1	7.6	<5	NO	460	<0.1	0
14	Yamuna Pd. Adhikari	7-20	27/01/2080	32.1	1	7.8	<5	NO	449	<0.1	0
15	Ramakant Sharma	8-A2	25/01/2080	31.4	2	6.5	<5	NO	262	<0.1	0
16	Sumitra Rana	9-08	27/01/2080	32.7	1	8.0	<5	NO	298	<0.1	0
17	Churna Dutt Suvedi	9-17	27/01/2080	31.9	2	7.6	<5	NO	450	<0.1	0
18	Puspa Raj Sapkota	10-1A	25/01/2080	30.4	1	7.3	<5	NO	629	<0.1	0
19	Diwakar Lamichane	10-02	27/01/2080	31.8	2	7.6	<5	NO	444	<0.1	0
20	Bed Maya giri	10-6A	27/01/2080	31.1	2	7.2	<5	NO	699	<0.1	0
21	Gadesh Paudel	10-12	25/01/2080	31.9	2	7.3	<5	NO	549	<0.1	0
22	khim maya Baral	7-16	25/01/2080	31.8	2	7.7	<5	NO	436	<0.1	0
23	Durga Maya Pradhan	10-15	25/01/2080	31.2	2	7.6	<5	NO	471	0.1	0
24	Matlab Miya	11-16	25/01/2080	30.3	2	7.6	<5	NO	477	<0.1	0
25	Shalik Ram Paudel	12-19	25/01/2080	31.6	1	7.5	<5	NO	501	<0.1	0
26	Hemlal Dahal	10-16	25/01/2080	30.9	2	7.3	<5	NO	463	<0.1	15
	Repeated sample		26/01/2080								0
27	ward no 12 karyalaya	12-5	25/01/2080	31.3	1	7.9	<5	NO	261	<0.1	0
28	Mina Kumari Paudel	14-25	27/01/2080	31.9	2	7.9	<5	NO	297	<0.1	0
29	Goma Thapa Chhetri	13165	27/01/2080	32.1	2	7.5	<5	NO	434	<0.1	0
30	Gopal Prasad Kandel	8-12	27/01/2080	31.4	1	7.7	<5	NO	399	<0.1	0
31	Blank		25/01/2080								>50
32	Contaminated Water with Cowdung		25/01/2080								

* These values show lower and Upper Limits

Tested By: Ram Krishna Khanal

Senior administration
Checked By: Sanjaya Baral
Officer

Approved By: Prajapatai Dahal
Executive Director