

**BHARATPUR WATER SUPPLY MANAGEMENT BOARD**

Bharatpur-Chitwan

**Drinking Water Quality Test Report of Randomly Selected Customers (SHRAWAN) 2080**



S.N	Customer Name	Name of Source	Customer ID	Area No	Date	Max. Concent. Limits, as per NDWQS-->	Temp. °C	Turbidity	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
1	Iman Bahadur Gurung	2905	2-01	24/04/2080	28.7	5(10)	6.5 to 8.5*	5(15)	<5	NO	1500	0.1-0.2	0	
2	Nabarai Dhakal	1859	2-15	24/04/2080	28.7	1	7.5	<5	6.6	NO	430	<0.1	0	
3	Bhim Maya Tamang	6393	2-23	24/04/2080	28.7	2	6.7	<5	NO	246	<0.1	0		
4	Bhakti Ram Gautam	390	3-04	24/04/2080	28.7	2	7.4	<5	NO	256	<0.1	0		
5	Chandra Mitra Pandit	14850	4-01	24/04/2080	28.5	1	7.5	<5	NO	450	<0.1	0		
6	Jagannath Kandel	12404	4-10	30/04/2080	30.3	2	7.7	<5	NO	545	<0.1	0		
7	Narayan Pd. Shrestha	7740	4-01A	24/04/2080	28.8	1	7.6	<5	NO	428	<0.1	0		
8	Hari Dash Sapkota	8810	6-18	30/04/2080	30.1	1	7.8	<5	NO	546	<0.1	0		
9	Khem Lal Suvedi	11565	6-18	30/04/2080	30.3	3	7.8	<5	NO	414	<0.1	0		
10	Jaya Prasad Sapkota	14255	6-19	30/04/2080	30.4	1	7.9	<5	NO	435	<0.1	0		
11	Radha Devi Khanal	4705	7-10	30/04/2080	29.9	1	7.8	<5	NO	383	<0.1	0		
12	Bhagawati Padhya	9305	7-12	30/04/2080	30.1	1	8.0	<5	NO	448	<0.1	0		
13	Krishna Prasad Risal	8195	7-20	30/04/2080	30.1	2	7.8	<5	NO	296	<0.1	0		
	Repeated Sample			32/04/2080						439	<0.1	0		
14	Yamuna Pd. Adhikari	9295	7-20	30/04/2080	30.5	2	7.7	<5	NO	436	<0.1	0		
15	Ramakant Sharma	623	8-A2	24/04/2080	28.9	2	6.6	<5	NO	242	<0.1	0		
16	Sumitra Rana	14200	9-08	30/04/2080	30.5	2	8.0	<5	NO	296	<0.1	0		
17	Churna Dutta Suvedi	11930	9-17	30/04/2080	29.6	2	7.7	<5	NO	392	<0.1	0		
18	Puspa Rai Sapkota	1380	10-1A	24/04/2080	29.4	1	7.5	<5	NO	525	<0.1	0		
19	Diwakar Lamichane	10770	10-02	30/04/2080	30.1	2	7.7	<5	NO	407	<0.1	0		
20	Bed Maya Giri	13210	10-6A	32/04/2080	29.8	3	7.3	<5	NO	698	<0.1	0		
21	Gadesh Paudel	4170	10-12	24/04/2080	29.2	2	7.3	<5	NO	586	<0.1	0		
	Repeated Sample			32/04/2080						3	0	0		
22	Khim maya Baral	16688	7-16	24/04/2080	29.3	1	7.5	<5	NO	594	<0.1	0		
23	Durga Maya Pradhan	6663	10-15	24/04/2080	28.7	1	7.7	<5	NO	406	0.1	0		
24	Maitlab Miya	3325	11-16	24/04/2080	28.4	2	7.8	<5	NO	389	<0.1	0		
25	Shalik Ram Paudel	12700	12-19	24/04/2080	28.9	2	7.5	<5	NO	486	<0.1	0		
26	Hemjal Dahal	15604	10-16	24/04/2080	28.8	2	7.9	<5	NO	390	<0.1	>20		
	Repeated Sample			32/04/2080										
27	ward no 12 kalyalaya	33210	12-5	24/04/2080	29.1	3	8.0	<5	NO	257	<0.1	0		
28	Mina Kumari Paudel	13810	14-25	30/04/2080	30.2	3	8.0	<5	NO	294	<0.1	0		
29	Goma Thapa Chhetri	13165	14-25	30/04/2080	30.3	3	7.8	<5	NO	412	<0.1	0		
30	Gopal Prasad Kandel	5800	8-12	30/04/2080	30.4	3	7.9	<5	NO	294	<0.1	0		
31	Blank			24/04/2080										
32	Contaminated Water with Cow dung			24/04/2080										

\* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Tested By:Ram Krishna Khanal

Senior Officer

Checked By:Sanjaya Baral

Chemist

Director

Approved By:Prajapatai Dahal