

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Drinking Water Quality Test Report for Regularly Selected Customers (FALGUN) 2080

SN	Name of Source		Date	Temp °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
	Area No	max. Concentration Limits, as per NDWQS									
1	Iman Bahadur Gurung	2-01	22/11/2080	23.4	2	7.7	<5	NO	452	<0.1	0
2	Nabaraj Dhakal	2-15	22/11/2080	23.8	2	6.6	<5	NO	255	<0.1	0
3	Bhim Maya Tamang	2-23	22/11/2080	23.8	2	7.2	<5	NO	374	<0.1	0
4	Bhakti Ram Gautam	3-04	22/11/2080	23.7	3	7.6	<5	NO	461	<0.1	0
5	Chandra Mitra Pandit	4-01	22/11/2080	23.6	2	7.5	<5	NO	534	<0.1	0
6	Jagannath Kandel	4-10	27/11/2080	24.8	2	7.6	<5	NO	381	<0.1	0
7	Narayan Pd Shrestha	4-01A	22/11/2080	23.6	1	7.6	<5	NO	532	<0.1	0
8	Hari Dash Sapkota	6-18	27/11/2080	25.2	2	7.6	<5	NO	467	<0.1	0
9	Khem Lal Suvedi	6-18	27/11/2080	25.3	2	7.9	<5	NO	292	<0.1	0
10	Jaya Prasad Sapkota	6-19	27/11/2080	25.4	2	7.6	<5	NO	382	<0.1	0
11	Radha Devi Khanal	7-10	27/11/2080	25.3	3	7.8	<5	NO	452	<0.1	0
12	Bhagawati Padya	7-12	27/11/2080	25.4	3	7.6	<5	NO	381	<0.1	0
13	Krishna Prasad Risal	7-20	27/11/2080	24.7	2	7.8	<5	NO	257	<0.1	0
14	Yamuna Pd Adhikari	7-20	27/11/2080	25.6	3	8.0	<5	NO	293	<0.1	0
15	Ramakant Sharma	8-A2	22/11/2080	23.7	2	6.6	<5	NO	260	<0.1	0
16	Sumitra Rana	9-08	27/11/2080	25.4	2	7.8	<5	NO	271	<0.1	0
17	Churna Dutta Suvedi	9-17	27/11/2080	25.6	2	7.6	<5	NO	309	<0.1	0
18	Puspa Raj Sapkota	10-1A	22/11/2080	23.4	2	7.4	<5	NO	522	<0.1	0
19	Diwakar Lamichane	10-02	27/11/2080	25.4	2	7.7	<5	NO	441	<0.1	0
20	Bed Maya giri	10-6A	27/11/2080	25.4	2	7.3	<5	NO	696	<0.1	0
21	Gadesh Paudel	10-12	22/11/2080	23.8	1	7.4	<5	NO	528	<0.1	0
22	Khim maya Baral	7-16	22/11/2080	23.8	2	7.4	<5	NO	558	<0.1	0
23	Durga Maya Pradhan	10-15	22/11/2080	23.6	1	7.7	<5	NO	450	0.1	0
24	Matlab Miya	11-16	22/11/2080	23.6	3	7.7	<5	NO	453	<0.1	0
25	Shalik Ram Paudel	12-19	22/11/2080	23.9	1	7.4	<5	NO	454	<0.1	0
26	Hemlal Dahal	10-16	22/11/2080	23.9	3	7.6	<5	NO	400	<0.1	0
27	ward no 12 karyalaya	12-5	22/11/2080	23.7	2	8.0	<5	NO	250	<0.1	0
28	Mina Kumari Paudel	14-25	27/11/2080	25.2	2	7.9	<5	NO	269	<0.1	0
29	Goma Thapa Chhetri	14-25	27/11/2080	25.2	1	8.0	<5	NO	293	<0.1	0
30	Gopal Prasad Kandel	8-12	27/11/2080	25.4	2	8.0	<5	NO	292	<0.1	0
31	Blank		22/11/2080								
32	Contaminated Water with Cowdung		22/11/2080								>50

* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Tested By: Ram Krishna Khanal

Checked By: Sanjaya Baral

for administration

Approved By: Prajapati Dahal