

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Drinking Water Quality Test Report of Monthly Selected Customers (BAISAKH) 2081

Chitwan

S.N	Name of Source		Date	Temp	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
	Area No	Max. Concent. Limits, as per NDWQS-->			5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
1	Iman Bahadur Gurung	2905	27/01/2081	26.8	2	7.7	<5	NO	474	<0.1	0
2	Nabaraj Dhakal	1859	27/01/2081	26.9	2	6.7	<5	NO	250	<0.1	0
3	Bhim Maya Tamang	6393	27/01/2081	26.9	2	7.5	<5	NO	430	<0.1	0
4	Bhakti Ram Gautam	390	27/01/2081	26.9	2	7.5	<5	NO	484	<0.1	0
5	Chandra Mira Pandit	14850	27/01/2081	26.6	2	7.5	<5	NO	541	<0.1	0
6	Jagannath Kandel	12404	24/01/2081	27.9	2	7.8	<5	NO	300	<0.1	0
7	Narayan Pd. Shrestha	7740	27/01/2081	26.6	2	7.6	<5	NO	540	<0.1	0
8	Hari Dash Sapkota	8810	24/01/2081	26.1	3	7.7	<5	NO	446	<0.1	0
9	Khem Lal Suvedi	11565	24/01/2081	26.7	3	7.7	<5	NO	418	<0.1	0
10	Jaya Prasad Sapkota	14255	24/01/2081	27.2	3	7.6	<5	NO	410	<0.1	0
11	Radha Dev. Khanal	4705	24/01/2081	26.4	3	7.7	<5	NO	455	<0.1	0
12	Bhadrawati Padhya	9305	24/01/2081	27.2	3	7.5	<5	NO	319	<0.1	0
13	Krishna Prasad Risal	8195	24/01/2081	26.7	3	7.7	<5	NO	366	<0.1	0
14	Yamuna Pd. Adhikari	9295	24/01/2081	27.5	2	7.4	<5	NO	500	<0.1	0
15	Ramakant Sharma	623	27/01/2081	26.7	2	7.0	<5	NO	365	<0.1	0
16	Sumitra Rana	14200	24/01/2081	26.2	2	7.3	<5	NO	562	<0.1	0
17	Churna Dulita Suvedi	11930	24/01/2081	26.1	3	7.5	<5	NO	444	<0.1	0
18	Puspa Rai Sapkota	1380	27/01/2081	26.4	2	7.4	<5	NO	525	<0.1	0
19	Dwarka Lamichane	10770	24/01/2081	27.1	1	7.5	<5	NO	445	<0.1	0
20	Bed Maya giri	13210	24/01/2081	27.7	2	7.2	<5	NO	707	<0.1	0
21	Gadesh Paudel	16688	27/01/2081	27.7	2	7.4	<5	NO	538	<0.1	0
22	Khim maya Baral	6663	27/01/2081	27.6	2	7.5	<5	NO	471	<0.1	0
23	Durga Maya Pradhan	3325	24/01/2081	27.9	2	7.6	<5	NO	450	<0.1	0
24	Matlab Miya	12700	27/01/2081	28.8	3	7.5	<5	NO	454	<0.1	0
25	Shalik Ram Paudel	15604	27/01/2081	27.6	2	7.6	<5	NO	480	<0.1	0
26	Hemlal Dahal	33210	27/01/2081	27.7	2	7.5	<5	NO	409	<0.1	0
27	ward no 12 karyalaya	13810	24/01/2081	26.9	2	7.8	<5	NO	256	<0.1	0
28	Mina Kumari Paudel	13165	24/01/2081	27.1	2	7.7	<5	NO	284	<0.1	0
29	Goma Thapa Chhetri	5800	24/01/2081	27.1	3	7.6	<5	NO	408	<0.1	0
30	Gopal Prasad Kandel		24/01/2081	27.1	3	7.7	<5	NO	397	<0.1	0
31	Blank		24/01/2081								
32	Contaminated Water with Cowdung		24/01/2081								>40

* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Tested By: Ram Krishna Khanal

Water Administration
Checked By: Sanjaya Baral

Approved By: Prajapatai Dahal