

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (SHRAWAN) 2081

S.N	Name of Source		Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
1	Iman Bahadur Gurung	2905	21/04/2081	30.3	1	7.8	<5	NO	449	<0.1	0
2	Nabaraj Dhakal	1859	21/04/2081	30.4	1	6.7	<5	NO	272	<0.1	10
3	Repaid sample	6393	32/04/2081	30.4	3	7.0	<5	NO	360	<0.1	0
4	Bhim Maya Tamang	390	21/04/2081	30.2	2	7.5	<5	NO	640	<0.1	0
5	Bhakti Ram Gautam	14850	21/04/2081	30.3	1	7.5	<5	NO	570	<0.1	0
6	Chandra Mitra Pandit	12404	27/04/2081	28.3	2	7.5	<5	NO	304	<0.1	0
7	Jagannath Kandel	7740	21/04/2081	30.2	2	7.6	<5	NO	549	<0.1	0
8	Narayan Pd. Shrestha	8810	21/04/2081	28.4	2	7.9	<5	NO	447	<0.1	0
9	Hari Dash Sapkota	11565	27/04/2081	29.2	2	8.0	<5	NO	300	<0.1	0
10	Khem Lal Suvedi	14255	27/04/2081	28.4	1	7.6	<5	NO	386	<0.1	0
11	Java Prasad Sapkota	4705	27/04/2081	28.3	1	7.9	<5	NO	448	<0.1	0
12	Radha Devi Khanal	9305	27/04/2081	28.2	1	7.9	<5	NO	298	<0.1	0
13	Bhagawati Padya	8195	27/04/2081	28.2	1	8.0	<5	NO	304	<0.1	0
14	Krishna Prasad Risal	9295	27/04/2081	28.3	1	7.9	<5	NO	373	<0.1	20
15	Yamuna Pd. Adhikari	8-A2	21/04/2081	30.5	1	6.7	<5	NO	277	<0.1	0
16	Ramakant Sharma	623	32/04/2081	28.2	1	8.0	<5	NO	298	<0.1	0
17	Sumitra Rana	14200	27/04/2081	28.4	2	7.6	<5	NO	490	<0.1	0
18	Churna Dutta Suvedi	11930	21/04/2081	30.2	3	7.6	<5	NO	481	<0.1	0
19	Puspa Raj Sapkota	10770	27/04/2081	28.2	1	7.8	<5	NO	439	<0.1	0
20	Diwakar Lamichane	13210	32/04/2081	28.4	1	7.4	<5	NO	707	<0.1	0
21	Repeated sample	4170	27/04/2081	30.7	3	7.4	<5	NO	555	<0.1	0
22	Bed Maya giri	16688	21/04/2081	30.7	2	7.7	<5	NO	398	<0.1	0
23	Gadesh Paudel	6663	21/04/2081	30.3	1	7.7	<5	NO	424	<0.1	0
24	Khim maya Baral	3325	27/04/2081	30.4	1	7.7	<5	NO	424	<0.1	14
25	Durga Maya Pradhan	12700	21/04/2081	31.4	2	7.5	<5	NO	512	<0.1	0
26	Matlab Miya	15604	32/04/2081	31.1	3	7.5	<5	NO	465	<0.1	15
27	Shalik Ram Paudel	33210	21/04/2081	30.7	3	7.9	<5	NO	259	<0.1	0
28	Repeated sample	13810	27/04/2081	29.3	2	7.8	<5	NO	276	<0.1	0
29	Mina Kumari Paudel	13165	27/04/2081	28.4	1	7.9	<5	NO	371	<0.1	0
30	Goma Thapa Chhetri	5800	27/04/2081	28.2	1	7.8	<5	NO	406	<0.1	0
31	Gopal Prasad Kandel	Blank	21/04/2081								>40
32	Contaminated Water with Cowdung		21/04/2081								

* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.



Tested By: Ram Krishya Khanal

Checked By: Sanjaya Baral


 Executive Director
 Approved: Sanjaya Baral