

# BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

## Drinking Water Quality Test Report of Randomly Selected Customers (Poush) 2081

S.N	Name of Source		Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
		Area No	Max. Concent. Limits, as per NDWQS-->		5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
1	Iman Bahadur Gurung	2-01	22/09/2081	19.3	3	7.8	<5	NO	513	<0.1	0
2	Nabataj Dhakal	2-15	22/09/2081	19.6	2	7.4	<5	NO	392	<0.1	0
3	Bhim Maya Tamang	2-23	22/09/2081	19.4	2	7.2	<5	NO	372	<0.1	0
4	Bhakti Ram Gautam	3-04	22/09/2081	19.7	3	7.7	<5	NO	540	<0.1	0
5	Chandra Mitra Pandit	4-01	22/09/2081	18.9	2	7.4	<5	NO	631	<0.1	0
6	Jagannath Kandel	4-10	26/09/2081	17.9	3	8.1	<5	NO	291	<0.1	0
7	Narayan Pd. Shrestha	4-01A	22/09/2081	19.3	3	7.6	<5	NO	507	<0.1	0
8	Hari Dash Sapkota	6-18	26/09/2081	18.1	3	7.9	<5	NO	437	<0.1	0
9	Khem Lal Suvedi	6-18	26/09/2081	17.9	3	7.3	<5	NO	293	<0.1	0
10	Jaya Prasad Sapkota	6-19	26/09/2081	18.6	3	7.8	<5	NO	379	<0.1	0
11	Radha Devi Khanal	7-10	26/09/2081	18.1	3	8.0	<5	NO	436	<0.1	0
12	Bhagawati Padhya	7-12	26/09/2081	17.9	3	8.0	<5	NO	291	<0.1	0
13	Krishna Prasad Risal	7-20	26/09/2081	17.5	2	7.8	<5	NO	387	<0.1	0
14	Yamuna Pd. Adhikari	7-20	26/09/2081	18.1	2	8.1	<5	NO	291	<0.1	0
15	Ramakant Sharma	8-A2	22/09/2081	19.9	2	7.1	<5	NO	311	<0.1	0
16	Sumitra Rana	9-08	26/09/2081	18.3	3	7.8	<5	NO	438	<0.1	0
17	Churna Dutta Suvedi	9-17	26/09/2081	19.3	3	7.7	<5	NO	475	<0.1	0
18	Puspa Raj Sapkota	10-1A	22/09/2081	19.1	3	7.8	<5	NO	478	<0.1	0
19	Diwakar Lamichane	10-02	26/09/2081	19.5	3	7.9	<5	NO	431	<0.1	0
20	Bed Maya giri	10-6A	26/09/2081	18.5	3	7.5	<5	NO	686	<0.1	0
21	Gadesh Paudel	10-12	22/09/2081	19.7	3	7.7	<5	NO	485	<0.1	0
22	Khim maya Baral	7-16	22/09/2081	19.4	2	7.8	<5	NO	392	<0.1	0
23	Durga Maya Pradhan	10-15	22/09/2081	19.7	3	7.9	<5	NO	441	0.1	0
24	Matlab Miya	11-16	26/09/2081	19.5	3	7.5	<5	NO	422	<0.1	0
25	Shalik Ram Paudel	12-19	22/09/2081	19.7	3	7.2	<5	NO	327	<0.1	0
26	Hemlal Dahal	10-16	22/09/2081	19.2	2	7.6	<5	NO	449	<0.1	0
27	ward no 12 karyalaya	12-5	22/09/2081	19.5	3	8.1	<5	NO	243	<0.1	0
28	Mina Kumari Paudel	14-25	26/09/2081	18.3	3	8.1	<5	NO	293	<0.1	0
29	Goma Thapa Chhetri	14-25	26/09/2081	18.2	2	8.1	<5	NO	329	<0.1	0
30	Gopal Prasad Kandel	8-12	26/09/2081	18.8	3	7.9	<5	NO	441	<0.1	0
31	Blank		22/09/2081								
32	Contaminated Water with Cowdung		22/09/2081								>50

\* These values show lower and Upper Limits  
Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Tested By: Ram Krishna Khatiwada  
**Chemist**

Executive Director  
Approved By: Sanjaya Baral