

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (MAGH) 2078

Name of Source		Customer ID	Area No	Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
Customer Name	Max. Concent. Limits, as per NDWQS-->											
Iman Bahadur Gurung	2905	2-01	20/10/2078	18.4	<2	7.6	<5	Non objectionable	1500	0.1-0.2	0	
Nabaraj Dhakal	1859	2-15	20/10/2078	18.8	1	7.4	<5	NO	362	<0.1	0	
Bhim Maya Tamang	6393	2-23	20/10/2078	18.6	<2	6.6	<5	NO	375	<0.1	0	
Bhakti Ram Gautam	390	3-04	20/10/2078	18.4	1	7.8	<5	NO	221	<0.1	0	
Chandra Mitra Pandit	14850	4-01	20/10/2078	18.8	<2	7.7	<5	NO	581	<0.1	0	
Jagannath Kandel	12404	4-10	24/10/2078	17.7	<2	7.8	<5	NO	543	<0.1	0	
Narayan Pd. Shrestha	7740	4-01A	20/10/2078	18.7	<2	7.5	<5	NO	408	<0.1	0	
Hari Dash Sapkota	8810	6-18	24/10/2078	17.7	1	7.8	<5	NO	664	<0.1	0	
Khem Lal Suvedi	11565	6-18	24/10/2078	18.1	1	7.9	<5	NO	405	<0.1	0	
Jaya Prasad Sapkota	14255	6-19	24/10/2078	17.4	2	7.8	<5	NO	409	<0.1	0	
Radha Devi Khanal	4705	7-10	24/10/2078	18.1	2	6.8	<5	NO	406	<0.1	0	
Bhagawati Padhya	9305	7-12	24/10/2078	17.4	1	7.7	<5	NO	263	<0.1	0	
Krishna Prasad Risal	8195	7-20	24/10/2078	18	2	7.6	<5	NO	412	<0.1	0	
Yamuna Pd. Adhikari	9295	7-20	24/10/2078	17.8	<2	7.6	<5	NO	396	<0.1	0	
Ramakant Sharma	623	8-A2	20/10/2078	18.9	2	6.7	<5	NO	414	<0.1	0	
Sumitra Rana	14200	9-08	24/10/2078	17.6	1	7.8	<5	NO	223	<0.1	0	
Churna Dutta Suvedi	11930	9-17	24/10/2078	17.6	1	7.8	<5	NO	403	<0.1	0	
Puspa Raj Sapkota	1380	10-1A	20/10/2078	19.2	2	7.8	<5	NO	412	<0.1	0	
Diwakar Lamichane	10770	10-02	24/10/2078	17.9	<2	7.8	<5	NO	404	<0.1	0	
Bed Maya giri	13210	10-6A	24/10/2078	17.6	2	7.8	<5	NO	403	<0.1	0	
Gadesh Paudel	4170	10-12	20/10/2078	18.3	1	7.5	<5	NO	406	<0.1	0	
khim maya Baral	16688	7-16	20/10/2078	18.2	1	8.0	<5	NO	611	<0.1	0	
Durga Maya Pradhan	6663	10-15	20/10/2078	18.7	2	8.0	<5	NO	403	<0.1	0	
Matlab Miya	3325	11-16	20/10/2078	18.3	1	7.9	<5	NO	410	0.1	0	
Shalik Ram Paudel	12700	12-19	20/10/2078	18.3	<2	7.8	<5	NO	407	<0.1	0	
Hemlal Dahal	15604	10-16	20/10/2078	17.8	1	7.8	<5	NO	453	<0.1	0	
ward no 12 karyalaya	33210	12-5	20/10/2078	18.3	2	8.1	<5	NO	494	<0.1	0	
Mina Kumari Paudel	13810	14-25	24/10/2078	17.7	1	7.7	<5	NO	245	<0.1	0	
Goma Thapa Chhetri	13165	14-25	24/10/2078	17.7	<2	7.8	<5	NO	418	<0.1	0	
Gopal Prasad Kandel	5800	8-12	24/10/2078	18.1	<2	6.9	<5	NO	413	<0.1	0	
Blank			20/10/2078						265	<0.1	0	
Contaminated Water with Cowdung			20/10/2078								>50	

These values show lower and Upper Limits

By: Ram Krishna Khanel

Executive Director
Santosh Baral