

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (Magh) 2079



| S.N | Name of Source | | Date | Temp. °C | Turbidity (NTU) | pH | Colour (TCU) | Taste and Odor | Electrical conductivity (µS/cm) | Residual Chlorine (mg/L) | Faecal C (CFU/100) |
|-----|---------------------------------|-------------|------------|----------|-----------------|-----|--------------|----------------|---------------------------------|--------------------------|--------------------|
| | Customer Name | Customer ID | | | | | | | | | |
| 1 | Iman Bahadur Gungu | 2905 | 29/10/2079 | 23.4 | 2 | 7.7 | <5 | NO | 461 | <0.1 | 0 |
| 2 | Nabarai Dhakal | 1859 | 29/10/2079 | 22.9 | 2 | 7.8 | <5 | NO | 602 | <0.1 | 0 |
| 3 | Bhim Maya Tamang | 6393 | 29/10/2079 | 23.6 | 2 | 7.7 | <5 | NO | 604 | <0.1 | 0 |
| 4 | Bhakti Ram Gautam | 390 | 29/10/2079 | 23.4 | 2 | 7.6 | <5 | NO | 461 | <0.1 | 0 |
| 5 | Chandra Mitra Pandit | 14850 | 29/10/2079 | 22.8 | 2 | 7.7 | <5 | NO | 461 | <0.1 | 0 |
| 6 | Jagannath Kandel | 12404 | 26/10/2079 | 22.4 | 1 | 7.8 | <5 | NO | 427 | <0.1 | 0 |
| 7 | Narayan Pd. Shrestha | 7740 | 29/10/2079 | 23.5 | 2 | 7.7 | <5 | NO | 462 | <0.1 | 0 |
| 8 | Hari Dash Sapkota | 8810 | 26/10/2079 | 22.8 | 2 | 7.8 | <5 | NO | 422 | <0.1 | 0 |
| 9 | Khem Lal Suvedi | 11565 | 26/10/2079 | 22.3 | 1 | 8.1 | <5 | NO | 283 | <0.1 | 0 |
| 10 | Jaya Prasad Sapkota | 14255 | 26/10/2079 | 22.3 | 2 | 7.7 | <5 | NO | 374 | <0.1 | 0 |
| 11 | Radha Devi Khanal | 4705 | 26/10/2079 | 21.9 | 2 | 7.4 | <5 | NO | 666 | <0.1 | 0 |
| 12 | Bhagwati Padhya | 9305 | 26/10/2079 | 22.3 | 2 | 7.7 | <5 | NO | 443 | <0.1 | 0 |
| 13 | Krishna Prasad Risal | 8195 | 26/10/2079 | 22.2 | 2 | 7.8 | <5 | NO | 435 | <0.1 | 0 |
| 14 | Yamuna Pd. Adhikari | 9295 | 26/10/2079 | 22.4 | 1 | 7.9 | <5 | NO | 254 | <0.1 | 0 |
| 15 | Ramakant Sharma | 623 | 29/10/2079 | 22.8 | 2 | 7.7 | <5 | NO | 604 | <0.1 | 0 |
| 16 | Sumitra Rana | 14200 | 26/10/2079 | 22.2 | 1 | 7.8 | <5 | NO | 374 | <0.1 | 0 |
| 17 | Churna Dutta Suvedi | 11930 | 26/10/2079 | 22.7 | 2 | 7.7 | <5 | NO | 424 | <0.1 | 0 |
| 18 | Puspa Raj Sapkota | 1380 | 29/10/2079 | 23.1 | 3 | 7.7 | <5 | NO | 460 | <0.1 | 0 |
| 19 | Diwakar Lamichane | 10770 | 26/10/2079 | 22.4 | 2 | 7.8 | <5 | NO | 431 | <0.1 | 0 |
| 20 | Bed Maya giri | 13210 | 26/10/2079 | 21.6 | 1 | 7.4 | <5 | NO | 648 | <0.1 | 0 |
| 21 | Gadesh Paudel | 4170 | 29/10/2079 | 21.8 | 1 | 7.6 | <5 | NO | 608 | <0.1 | 0 |
| 22 | Khim maya Baral | 16688 | 29/10/2079 | 21.7 | 1 | 7.6 | <5 | NO | 503 | <0.1 | 0 |
| 23 | Durga Maya Pradhan | 6663 | 29/10/2079 | 23.2 | 3 | 7.7 | <5 | NO | 602 | 0.1 | 0 |
| 24 | Mallab Miya | 3325 | 29/10/2079 | 22.1 | 1 | 7.8 | <5 | NO | 435 | <0.1 | 0 |
| 25 | Shalik Ram Paudel | 12700 | 29/10/2079 | 22.6 | 2 | 7.7 | <5 | NO | 492 | <0.1 | 0 |
| 26 | Hemlal Dahal | 15604 | 29/10/2079 | 22.8 | 2 | 7.7 | <5 | NO | 459 | <0.1 | 0 |
| 27 | ward no 12 karyalaya | 33210 | 29/10/2079 | 22.2 | 2 | 8.0 | <5 | NO | 295 | <0.1 | 0 |
| 28 | Mina Kumari Paudel | 13810 | 26/10/2079 | 22.1 | 2 | 7.7 | <5 | NO | 434 | <0.1 | 0 |
| 29 | Goma Thapa Chhetri | 13165 | 26/10/2079 | 21.8 | 1 | 8.0 | <5 | NO | 426 | <0.1 | 0 |
| 30 | Gopal Prasad Kandel | 5800 | 26/10/2079 | 22.1 | 2 | 7.8 | <5 | NO | 373 | <0.1 | 0 |
| 31 | Blank | | 26/10/2079 | | | | | | | | |
| 32 | Contaminated Water with Cowdung | | 26/10/2079 | | | | | | | | |

* These values show lower and Upper Limits

Tested By: Ram Krishna Khanal

Chemist

Checked By: Suresh Baral

Administration

Executive Director

Approved By: P. Raj