



BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Drinking Water Quality Test Report of Randomly Selected Customers (BAISAKH) 2079

S.N	Name of Source		Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
			Max. Concent. Limits, as per NDWQS-->		5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
1	Iman Bahadur Gurung	2905	23/01/2079	26.1	1	7.6	<5	NO	437	<0.1	0
2	Nabaraj Dhakal	1859	23/01/2079	26.8	1	6.7	<5	NO	223	<0.1	0
3	Bhim Maya Tamang	6393	23/01/2079	27.1	1	6.6	<5	NO	463	<0.1	0
4	Bhakti Ram Gautam	390	23/01/2079	26.8	1	7.7	<5	NO	509	<0.1	0
5	Chandra Mitra Pandit	14850	23/01/2079	26.4	1	7.7	<5	NO	504	<0.1	0
6	Jagannath Kandel	12404	20/01/2079	28.9	1	7.9	<5	NO	387	<0.1	0
7	Narayan Pd. Shrestha	7740	23/01/2079	26.6	1	7.7	<5	NO	504	<0.1	0
8	Hari Dash Sapkota	8810	20/01/2079	29.1	2	8.0	<5	NO	407	<0.1	0
9	Khem Lal Suvedi	11565	20/01/2079	28.9	1	7.9	<5	NO	387	<0.1	0
10	Jaya Prasad Sapkota	14255	20/01/2079	28.9	1	7.9	<5	NO	370	<0.1	0
11	Radha Devi Khanal	4705	20/01/2079	28.3	1	8.0	<5	NO	426	<0.1	0
12	Bhagawati Padhya	9305	20/01/2079	29.1	<2	7.9	<5	NO	499	<0.1	0
13	Krishna Prasad Risal	8195	20/01/2079	28.9	<2	7.8	<5	NO	488	<0.1	0
14	Yamuna Pd. Adhikari	9295	20/01/2079	30.1	1	8.0	<5	NO	388	<0.1	0
15	Ramakant Sharma	623	23/01/2079	29.9	1	7.3	<5	NO	334	<0.1	0
16	Sumitra Rana	14200	20/01/2079	29.2	1	7.9	<5	NO	388	<0.1	0
17	Churna Dutta Suvedi	11930	20/01/2079	28.5	1	7.9	<5	NO	415	<0.1	0
18	Puspa Raj Sapkota	1380	23/01/2079	26.2	1	7.6	<5	NO	460	<0.1	0
19	Diwakar Lamichane	10770	20/01/2079	28.7	<2	7.7	<5	NO	581	<0.1	0
20	Bed Maya giri	13210	20/01/2079	28.8	<2	7.6	<5	NO	685	<0.1	0
21	Gadesh Paudel	4170	23/01/2079	26.8	1	7.6	<5	NO	463	<0.1	0
22	Khim maya Baral	16688	23/01/2079	26.8	1	7.6	<5	NO	462	<0.1	0
23	Durga Maya Pradhan	6663	23/01/2079	26.1	1	7.6	<5	NO	461	0.1	0
24	Matlab Miya	3325	23/01/2079	27.3	1	7.7	<5	NO	463	<0.1	0
25	Shalik Ram Paudel	12700	23/01/2079	26.9	1	7.7	<5	NO	461	<0.1	0
26	Hemlal Dahal	15604	23/01/2079	26.9	1	7.7	<5	NO	462	<0.1	0
27	ward no 12 kanyalaya	33210	23/01/2079	26.9	1	7.7	<5	NO	459	<0.1	0
28	Mina Kumari Paudel	13810	20/01/2079	28.9	<2	7.9	<5	NO	241	<0.1	0
29	Goma Thapa Chhetri	13165	20/01/2079	28.9	2	7.9	<5	NO	387	<0.1	0
30	Gopal Prasad Kandel	5800	20/01/2079	28.9	2	8.0	<5	NO	383	<0.1	0
31	Blank		23/01/2079								>50
32	Contaminated Water with Cowdung		23/01/2079								

* These values show lower and Upper Limits

Tested By: Ram Krishna Kandel

Asst. Administration Officer Baral

[Signature]

Executive Officer Approved By: Prajapatai Dahal

[Signature]