

BHAJIPUR WATER SUPPLY MANAGEMENT BOARD

Charanpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (MANGSIR) 2079

Customer Name	Name of Source		Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer ID	Area No									
Iman Bahadur Gurung	2905	2-01	Max. Concent. Limits, as per NIDMAS 25/08/2079	21.2	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
Nabaraj Dhakal	1859	2-15	25/08/2079	21.7	3	7.7	<5	NO	415	<0.1	0
Bhim Maya Tamang	6393	2-23	25/08/2079	21.6	2	6.7	<5	NO	242	<0.1	0
Bhakti Ram Gautam	390	3-04	25/08/2079	20.7	2	6.8	<5	NO	242	<0.1	0
Chandra Mitra Pandit	14850	4-01	25/08/2079	20.6	2	7.9	<5	NO	511	<0.1	0
Jagannath Kandel	12404	4-10	25/08/2079	22.2	2	7.9	<5	NO	428	<0.1	0
Narayan Pd. Shrestha	7740	4-01A	25/08/2079	21.6	2	8.0	<5	NO	280	<0.1	0
Repeated sample			29/08/979			7.9	<5	NO	441	<0.1	>20
Hari Dash Sapkota	8810	6-18	27/08/2079	22.2	1	7.8	<5	NO	426	<0.1	0
Khem Lal Suvedi	11565	6-18	27/08/2079	22.1	1	8.1	<5	NO	279	<0.1	0
Jaya Prasad Sapkota	14255	6-19	27/08/2079	21.8	2	7.8	<5	NO	374	<0.1	0
Radha Devi Khanal	4705	7-10	27/08/2079	20.9	2	7.5	<5	NO	609	<0.1	0
Bhagawati Padiya	9305	7-12	27/08/2079	21.7	1	8.1	<5	NO	282	<0.1	0
Krishna Prasad Risal	8195	7-20	27/08/2079	21.5	2	7.8	<5	NO	481	<0.1	0
Yamuna Pd. Adhikari	9295	7-20	27/08/2079	22.1	1	8.2	<5	NO	281	<0.1	0
Ramakant Sharma	623	8-A2	25/08/2079	21.4	3	7.0	<5	NO	244	<0.1	3
Repeated sample			29/08/2079								0
Sumitra Rana	14200	9-08	27/08/2079	21.9	1	8.1	<5	NO	284	<0.1	0
Churna Dutta Suvedi	11930	9-17	27/08/2079	22.4	2	7.8	<5	NO	390	<0.1	0
Puspa Raj Sapkota	1380	10-1A	25/08/2079	20.9	1	7.7	<5	NO	488	<0.1	0
Diwakar Lamichane	10770	10-02	27/08/2079	21.2	1	7.9	<5	NO	439	<0.1	0
Bed Maya giri	13210	10-6A	27/08/2079	22.3	1	7.4	<5	NO	607	<0.1	0
Gadesh Paudel	4170	10-12	25/08/2079	21.1	2	7.4	<5	NO	667	<0.1	0
khim maya Baral	16688	7-16	25/08/2079	21.5	1	7.9	<5	NO	434	<0.1	0
Durga Maya Pradhan	6663	10-15	25/08/2079	20.7	2	7.9	<5	NO	425	0.1	4
Repeated sample			29/08/2079								0
Matlab Miya	3325	11-16	25/08/2079	21.6	1	8.0	<5	NO	428	<0.1	0
Shalik Ram Paudel	12700	12-19	25/08/2079	21.6	1	7.8	<5	NO	483	<0.1	0
Hemlal Dahal	15604	10-16	25/08/2079	21	1	8.2	<5	NO	443	<0.1	12
Repeated sample			29/08/2079								0
ward no 12 karyalaya	33210	12-5	25/08/2079	21.4	1	8.1	<5	NO	266	<0.1	7
Repeated sample			29/08/2079								0
Mina Kumari Paudel	13810	14-25	27/08/2079	21.9	2	8.1	<5	NO	281	<0.1	0
Goma Thapa Chhetri	13165	14-25	27/08/2079	22.1	2	8.1	<5	NO	280	<0.1	0
Gopal Prasad Kandel	5800	8-12	27/08/2079	22.1	1	8.1	<5	NO	288	<0.1	0
Blank			25/08/2079								0
Contaminated Water with Cowdung			25/08/2079								>50

\* These values show lower and Upper Limits  
 Tested By: Ram Krishna Khanal  
 Charanpur, Chitwan

Officer  
 Approved By: Prapat Dalal

Executive Director  
 Approved By: Prapat Dalal