

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Baharapur, Chitwan

Drinking Water Quality Report of Randomly Selected Customers (ASHWIN) 2079

Name of Source		Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
Customer ID	Area No	Max. Concentration Limits, as per NDWQS-->		5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
2905	2-01	26/06/2079	27.2	1	7.1	<5	NO	310	<0.1	0
1859	2-15	26/06/2079	27.5	1	6.5	<5	NO	249	<0.1	0
6393*	2-23	26/06/2079	27.6	1	7.0	<5	NO	302	<0.1	0
390	3-04	26/06/2079	27.4	1	7.6	<5	NO	609	<0.1	0
14850	4-01	26/06/2079	27.1	1	7.6	<5	NO	503	<0.1	0
12404	4-10	28/06/2079	28.8	1	7.9	<5	NO	384	<0.1	0
7740	4-01A	26/06/2079	27.4	1	7.6	<5	NO	503	<0.1	0
8810	6-18	28/06/2079	28.9	2	7.9	<5	NO	449	<0.1	0
11565	6-18	28/06/2079	28.8	2	8.1	<5	NO	304	<0.1	0
14255	6-19	28/06/2079	28.9	2	7.8	<5	NO	383	<0.1	0
4705	7-10	28/06/2079	28.5	2	7.9	<5	NO	446	<0.1	0
9305	7-12	28/06/2079	27.8	2	7.8	<5	NO	428	<0.1	0
8195	7-20	28/06/2079	27.9	2	7.6	<5	NO	589	<0.1	0
9295	7-20	28/06/2079	28.8	2	8.1	<5	NO	287	<0.1	0
623	8-A2	26/06/2079	27.1	2	6.6	<5	NO	253	<0.1	0
14200	9-08	28/06/2079	29.3	2	8.1	<5	NO	288	<0.1	0
11930	9-17	28/06/2079	27.8	1	7.9	<5	NO	387	<0.1	0
1380	10-1A	26/06/2079	27.1	2	7.5	<5	NO	585	<0.1	0
10770	10-02	28/06/2079	27.9	2	7.8	<5	NO	491	<0.1	0
13210	10-6A	28/06/2079	28.4	2	7.5	<5	NO	655	<0.1	0
4170	10-12	26/06/2079	27.6	1	7.3	<5	NO	688	<0.1	0
16688	7-16	26/06/2079	27.8	1	7.8	<5	NO	449	<0.1	0
6663	10-15	26/06/2079	27.2	1	7.3	<5	NO	404	0.1	0
3325	11-16	26/06/2079	27.4	1	7.9	<5	NO	385	<0.1	0
12700	12-19	26/06/2079	27.8	1	7.6	<5	NO	542	<0.1	0
15504	10-16	26/06/2079	27.6	1	7.5	<5	NO	488	<0.1	0
33210	12-5	26/06/2079	27.5	1	8.0	<5	NO	256	<0.1	0
13810	14-25	28/06/2079	28.8	2	8.2	<5	NO	285	<0.1	0
13165	14-25	28/06/2079	28.9	2	7.8	<5	NO	436	<0.1	0
5800	8-12	28/06/2079	28.3	2	8.0	<5	NO	443	<0.1	0
1	Blank									>50
2	Contaminated Water with Cowdung	26/06/2079								

* These values show lower and Upper Limits

Checked By: Ram Krishna Khatiwala

Water Administration
Checked By: Sanjaya Baral

Approved By: Dinesh Patai Dahal
Executive Engineer