

BHARATPUR MUNICIPAL SUPPLY MANAGEMENT BOARD



Drinking Water Quality Test Report on Randomly Selected Customers (BHADRA) 2079

S.N	Name of Source		Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
			Max. Concent. Limits, as per NDWQS-->	° C	5 (10)	6.5 to 8.5*	5 (15)	Non objectionable	1500	0.1-0.2	0
1	Iman Bahadur Gurung	2905	26/05/2079	29.1	1	7.3	<5	NO	389	<0.1	0
2	Nabatraj Dhakal	1859	26/05/2079	29.2	1	6.4	<5	NO	244	<0.1	0
3	Bhim Maya Tamang	6393	26/05/2079	28.9	1	6.8	<5	NO	293	<0.1	0
4	Bhakti Ram Gautam	390	26/05/2079	29.1	1	7.7	<5	NO	535	<0.1	0
5	Chandra Mitra Pandit	14850	26/05/2079	28.6	1	7.7	<5	NO	452	<0.1	0
6	Jagannath Kandel	12404	29/05/2079	27.8	2	8.1	<5	NO	284	<0.1	0
7	Narayan Pd. Shrestha	7740	26/05/2079	28.6	2	7.7	<5	NO	467	<0.1	0
8	Hari Dash Sapkota	8810	29/05/2079	27.8	2	7.8	<5	NO	437	<0.1	0
9	Khem Lal Suvedi	11565	29/05/2079	27.8	1	8.1	<5	NO	284	<0.1	0
10	Jaya Prasad Sapkota	14255	29/05/2079	28.1	2	7.7	<5	NO	381	<0.1	0
11	Radha Devi Khanal	4705	29/05/2079	27.7	2	7.8	<5	NO	441	<0.1	0
12	Bhagawati Padhya	9305	29/05/2079	27.9	2	8.1	<5	NO	284	<0.1	0
13	Krishna Prasad Risal	8195	29/05/2079	27.8	1	7.8	<5	NO	444	<0.1	0
14	Yamuna Pd. Adhikari	9295	29/05/2079	27.9	1	8.1	<5	NO	285	<0.1	0
15	Ramakant Sharma	623	26/05/2079	28.9	1	6.5	<5	NO	243	<0.1	0
16	Sumitra Rana	14200	29/05/2079	28.1	2	7.9	<5	NO	267	<0.1	0
17	Churna Dutta Suvedi	11930	29/05/2079	27.8	2	7.7	<5	NO	443	<0.1	0
18	Puspa Raj Sapkota	1380	26/05/2079	29.4	1	7.3	<5	NO	384	<0.1	0
19	Diwakar Lamichane	10770	29/05/2079	27.8	2	7.8	<5	NO	442	<0.1	0
20	Bed Maya giri	13210	29/05/2079	28.1	1	7.4	<5	NO	676	<0.1	0
21	Gadesh Paudel	4170	26/05/2079	30.1	1	7.3	<5	NO	694	<0.1	0
22	khim maya Baral	16688	26/05/2079	30.1	1	7.7	<5	NO	446	<0.1	0
23	Durga Maya Pradhan	6663	26/05/2079	28.9	1	7.7	<5	NO	450	0.1	0
24	Matlab Miya	3325	26/05/2079	29.4	1	7.8	<5	NO	424	<0.1	0
25	Shalik Ram Paudel	12700	26/05/2079	29.8	1	7.6	<5	NO	500	<0.1	0
26	Hemlal Dahal	15604	26/05/2079	29.9	1	7.9	<5	NO	391	<0.1	0
27	ward no 12 karyalaya	33210	26/05/2079	29.8	1	7.8	<5	NO	336	<0.1	0
28	Mina Kumari Paudel	13810	29/05/2079	27.9	2	8.0	<5	NO	285	<0.1	0
29	Goma Thapa Chhetri	13165	29/05/2079	27.6	1	7.9	<5	NO	283	<0.1	0
30	Gopal Prasad Kandel	5800	29/05/2079	27.9	2	7.7	<5	NO	286	<0.1	0
31	Blank		26/05/2079								0
32	Contaminated Water with Cowdung		26/05/2079								>50

* These values show lower and Upper Limits

Tested By: Ram Krishna Khanal
 Chemist

Senior administration

Checked By: Sanjaya Baral

Executive Director
 Prajapatai Dahal