



BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (ASHADH) 2079

S.N	Name of Source		Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
			Max. Concent. Limits, as per NDWQS→			6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
1	Iman Bahadur Gurung	2905	23/03/2079	29.9	2	7.8	<5	NO	470	<0.1	0
2	Nabaraj Dhakal	1859	23/03/2079	30.1	2	7.8	<5	NO	470	<0.1	0
3	Bhim Maya Tamang	6393	23/03/2079	29.5	1	7.8	<5	NO	470	<0.1	0
4	Bhakti Ram Gautam	390	23/03/2079	30	2	7.8	<5	NO	470	<0.1	0
5	Chandra Mitra Pandit	14850	23/03/2079	29.9	2	7.8	<5	NO	470	<0.1	0
6	Jagannath Kandel	12404	20/03/2079	29.9	<1	8.2	<5	NO	286	<0.1	0
7	Narayan Pd. Shrestha	7740	23/03/2079	29.9	2	7.8	<5	NO	471	<0.1	0
8	Hari Dash Sapkota	8810	20/03/2079	30	2	8.0	<5	NO	305	<0.1	0
9	Khem Lal Suvedi	11565	20/03/2079	29.8	1	8.1	<5	NO	285	<0.1	0
10	Jaya Prasad Sapkota	14255	20/03/2079	29.9	2	8.1	<5	NO	428	<0.1	0
11	Radha Devi Khanal	4705	20/03/2079	29.9	2	7.3	<5	NO	690	<0.1	0
12	Bhagawati Padhya	9305	20/03/2079	29.9	1	8.1	<5	NO	288	<0.1	0
13	Krishna Prasad Risal	8195	20/03/2079	29.7	1	8.0	<5	NO	304	<0.1	0
14	Yamuna Pd. Adhikari	9295	20/03/2079	29.6	2	8.1	<5	NO	286	<0.1	0
15	Ramakant Sharma	623	23/03/2079	29.9	2	7.8	<5	NO	471	<0.1	0
16	Sumitra Rana	14200	20/03/2079	29.8	1	8.2	<5	NO	285	<0.1	0
17	Churna Dutta Suvedi	11930	20/03/2079	29.5	<1	7.9	<5	NO	383	<0.1	0
18	Puspa Raj Sapkota	1380	23/03/2079	29.7	1	7.7	<5	NO	467	<0.1	0
19	Diwakar Lamichane	10770	20/03/2079	29.8	1	8.0	<5	NO	305	<0.1	0
20	Bed Maya giri	13210	20/03/2079	29.6	1	7.5	<5	NO	688	<0.1	0
21	Gadesh Paudel	4170	23/03/2079	30.1	1	7.7	<5	NO	473	<0.1	0
22	khim maya Baral	16688	23/03/2079	29.4	1	7.8	<5	NO	469	<0.1	0
23	Durga Maya Pradhan	6663	23/03/2079	29.9	2	7.8	<5	NO	471	<0.1	0
24	Matlab Miya	3325	23/03/2079	30	2	7.8	<5	NO	470	<0.1	0
25	Shalik Ram Paudel	12700	23/03/2079	29.4	1	7.8	<5	NO	469	<0.1	0
26	Hemlal Dahal	15604	23/03/2079	29.5	2	7.8	<5	NO	469	<0.1	0
27	ward no 12 karyalaya	33210	23/03/2079	29.9	2	7.8	<5	NO	470	<0.1	0
28	Mina Kumari Paudel	13810	20/03/2079	30.1	1	8.1	<5	NO	286	<0.1	0
29	Goma Thapa Chhetri	13165	20/03/2079	29.7	1	8.1	<5	NO	285	<0.1	0
30	Gopal Prasad Kandel	5800	20/03/2079	30.1	2	8.0	<5	NO	305	<0.1	0
31	Blank		20/03/2079								
32	Contaminated Water with Cowdung		20/03/2079								>50

* These values show lower and Upper Limits

Chemist

Asst. Administration Officer

Checked By: Sanjaya Baral

Signature

Executive Director

Approved By: Prajapatai Dahal

Tested By: Ram Krishna Khanal