

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

 Bharatpur Chitwan
 भरतपुर चित्वान

Drinking Water Quality Test Report of Randomly Selected Customers (Chaitra) 2079

Name of Source		Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
Customer Name	Customer ID	Max. Concent. Limits, as per NDWQS	0 C	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
Iman Bahadur Gurung	2905	2-01	20/12/2079	25.9	1	7.6	<5	475	<0.1	0
Nabaraj Dhakal	1859	2-15	20/12/2079	27.2	2	6.7	<5	NO	<0.1	0
Bhim Maya Tamang	6393	2-23	20/12/2079	27.2	1	7.0	<5	NO	405	<0.1
Bhakti Ram Gautam	390	3-04	20/12/2079	27.4	1	7.5	<5	NO	552	<0.1
Chandra Mitra Pandit	14850	4-01	20/12/2079	26.9	2	7.5	<5	NO	443	<0.1
Jagannath Kandel	12404	4-10	22/12/2079	27.6	2	7.7	<5	NO	438	<0.1
Narayan Pd. Shrestha	7740	4-01A	20/12/2079	26.7	1	7.6	<5	NO	552	<0.1
Hari Dash Sapkota	8810	6-18	22/12/2079	29.6	1	7.8	<5	NO	452	<0.1
Khem Lal Suvedi	11565	6-18	22/12/2079	27.8	2	7.6	<5	NO	437	<0.1
Jaya Prasad Sapkota	14255	6-19	22/12/2079	28.9	1	7.7	<5	NO	383	<0.1
Radha Devi Khanal	4705	7-10	22/12/2079	28.5	1	7.7	<5	NO	439	<0.1
Bhagawati Padhya	9305	7-12	22/12/2079	28.7	2	7.4	<5	NO	504	<0.1
Kristina Prasad Risal	8195	7-20	22/12/2079	28.3	2	7.4	<5	NO	370	<0.1
Yamuna Pd. Adhikari	9295	7-20	22/12/2079	27.1	2	7.3	<5	NO	643	<0.1
Ramakant Sharma	623	8-A2	20/12/2079	25.9	2	6.5	<5	NO	251	<0.1
Sumitra Rana	14200	9-08	22/12/2079	28.3	1	7.2	<5	NO	687	<0.1
Churna Dutta Suvedi	11930	9-17	22/12/2079	27.4	2	7.3	<5	NO	616	<0.1
Puspa Raj Sapkota	1380	10-1A	20/12/2079	25.7	2	7.3	<5	NO	453	<0.1
Diwakar Lamichane	10770	10-02	22/12/2079	29.8	1	7.7	<5	NO	688	<0.1
Bed Maya qiri	13210	10-6A	20/12/2079	27.7	2	7.3	<5	NO	538	<0.1
Gadesh Paudel	4170	10-12	20/12/2079	28.4	1	7.5	<5	NO	403	<0.1
Khim maya Baral	16688	7-16	20/12/2079	27.9	1	7.7	<5	NO	2	0
Repeated sample			23/12/2079						476	0.1
Durga Maya Pradhan	6663	10-15	20/12/2079	26.7	1	7.6	<5	NO	475	<0.1
Mailab Miya	33225	11-16	20/12/2079	26.3	2	7.5	<5	NO	508	<0.1
Shalik Ram Paudel	12700	12-19	20/12/2079	27.9	1	7.6	<5	NO	474	<0.1
Hemlal Dahal	15604	10-16	20/12/2079	28.7	1	7.6	<5	NO	257	<0.1
Repeated sample			23/12/2079						293	0
ward no 12 karyala	33210	12-5	20/12/2079	27.4	1	8.0	<5	NO	687	<0.1
Mira Kumari Paudel	13810	14-25	22/12/2079	29.4	2	7.8	<5	NO	378	<0.1
Goma Thapa Chhetri	13165	14-25	22/12/2079	29.3	1	7.3	<5	NO	0	0
Gopal Prasad Kandel	5800	8-12	22/12/2079	28.1	1	7.8	<5	NO		
Blank			20/12/2079							>50
Contaminated Water with Cow dung			20/12/2079							
Tested By: Ram Krishna Khanal										

* These values show lower and upper limits than the range as per the NDWQS 2079 for drinking water.
 Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.
 Checked By: Sanjaya Baral
 Approved By: Prajapatai Dahal
 Executive Director
 BHARATPUR WATER SUPPLY MANAGEMENT BOARD
 Bharatpur Chitwan
 BHARATPUR CHITWAN