

BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers (Falgun) 2079

S.N	Name of Source		Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
1	Iman Bahadur Gurung	2905	2-01	26/11/2079	27.4	1	7.4	Non objectionable	1500	0.1-0.2	0
2	Nabarej Dhakal	1859	2-15	26/11/2079	27.9	1	6.7	NO	440	<0.1	0
3	Bhim Maya Tamang	6393	2-23	26/11/2079	27.4	1	6.6	NO	262	<0.1	0
4	Bhakti Ram Gautam	390	3-04	26/11/2079	27.7	1	7.1	NO	234	<0.1	0
5	Chandra Mitra Pandit	14850	4-01	26/11/2079	25.2	2	7.7	NO	425	<0.1	0
6	Jagannath Kandel	12404	4-10	16/11/2079	25	2	8.1	NO	443	<0.1	0
7	Narayan Pd. Shrestha	7740	4-01A	26/11/2079	27.1	2	7.6	NO	287	<0.1	0
8	Hari Dash Sapkota	8810	6-18	16/11/2079	25.4	2	7.7	NO	597	<0.1	0
9	Khem Lal Suvedi	11565	6-18	16/11/2079	25.3	1	8.0	NO	436	<0.1	0
10	Jaya Prasad Sapkota	14255	6-19	16/11/2079	25.3	3	7.7	NO	287	<0.1	0
11	Radha Devi Khanal	4705	7-10	16/11/2079	24.6	2	7.3	NO	378	<0.1	0
12	Bhagawati Padiya	9305	7-12	16/11/2079	25.4	1	7.7	NO	674	<0.1	0
13	Krishna Prasad Risal	8195	7-20	16/11/2079	25.2	1	7.4	NO	433	<0.1	0
14	Yamuna Pd. Adhikari	9295	7-20	16/11/2079	25.4	2	7.8	NO	573	<0.1	0
15	Ramakant Sharma	623	8-A2	26/11/2079	27.8	1	6.7	NO	437	<0.1	0
16	Sumitra Rana	14200	9-08	16/11/2079	25.6	2	7.7	NO	279	<0.1	0
17	Churna Dutta Suvedi	11930	9-17	16/11/2079	25.1	2	7.7	NO	432	<0.1	0
18	Puspa Raj Sapkota	1380	10-1A	26/11/2079	25.6	2	7.4	NO	387	<0.1	0
19	Diwakar Lamichane	10770	10-02	16/11/2079	25.2	1	7.8	NO	612	<0.1	0
20	Bed Maya giri	13210	10-6A	16/11/2079	25.1	2	7.4	NO	441	<0.1	0
21	Gadesh Paudel	4170	10-12	26/11/2079	26.4	1	7.4	NO	675	<0.1	0
22	khim maya Baral	16688	7-16	26/11/2079	26.3	1	7.5	NO	528	<0.1	0
23	Durga Maya Pradhan	6663	10-15	26/11/2079	27.3	2	7.6	NO	489	<0.1	0
24	Matlab Miya	3325	11-16	26/11/2079	27.1	2	7.7	NO	438	0.1	0
25	Shalik Ram Paudel	12700	12-19	26/11/2079	26.8	2	7.6	NO	472	<0.1	0
26	Hemlal Dahal	15604	10-16	26/11/2079	25.9	2	7.7	NO	472	<0.1	0
27	ward no 12 karyalaya	33210	12-5	26/11/2079	26.9	2	7.7	NO	473	<0.1	0
28	Mina Kumari Paudel	13810	14-25	16/11/2079	25.5	1	8.0	NO	474	<0.1	0
29	Goma Thapa Chhetri	13165	14-25	16/11/2079	25.4	2	7.7	NO	288	<0.1	0
30	Gopal Prasad Kandel	5800	8-12	16/11/2079	25.4	1	8.1	NO	378	<0.1	0
31	Blank			16/11/2079					287	<0.1	0
32	Contaminated Water with Cowdung			16/11/2079							>50

* These values show lower and Upper Limits

Chemist

Tested By: Ram Krishna Khanal

Senior administration
Checked By: Sanjaya Baral

16/11/2079
Approved & Prepared
Executive Director