


BHARATPUR WATER SUPPLY MANAGEMENT BOARD

Drinking Water Quality Test Report for Randomly Selected Customers (SHRAWAN) 2079



S.N	Name of Source		Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (μ S/cm)	Residual Chlorine (mg/L)	Faecal Coli (CFU/100ml)
	Customer Name	Customer ID									
1	Iman Bahadur Gurung	2905	2-01	24/04/2079	30.2	2	7.8	<5	428	<0.1	0
2	Nabaraj Dhakal	1859	2-15	24/04/2079	30.1	2	7.9	<5	423	<0.1	0
3	Bhim Maya Tamang	6393	2-23	24/04/2079	30.5	1	6.8	<5	245	<0.1	0
4	Bhakti Ram Gautam	390	3-04	24/04/2079	30.0	1	7.9	<5	462	<0.1	0
5	Chandra Mitra Pandit	14850	4-01	24/04/2079	29.8	1	8.0	<5	447	<0.1	0
6	Jagamath Kandel	12404	4-10	30/04/2079	31.5	1	8.1	<5	285	<0.1	0
7	Narayan Pd. Shrestha	7740	4-01A	24/04/2079	30.2	2	8.0	<5	495	<0.1	0
8	Hari Dash Sappkota	8810	6-18	30/04/2079	31.2	1	7.6	<5	435	<0.1	0
9	Khem Lal Suvedi	11565	6-18	30/04/2079	31.4	1	8.1	<5	287	<0.1	0
10	Jaya Prasad Sappkota	14255	6-19	30/04/2079	31.1	1	7.7	<5	380	<0.1	0
11	Radha Devi Khanal	4705	7-10	30/04/2079	32.1	1	7.4	<5	644	<0.1	0
12	Bhagawati Padya	9305	7-12	30/04/2079	31.9	1	8.0	<5	289	<0.1	0
13	Krishna Prasad Risal	8195	7-20	30/04/2079	31.8	1	7.5	<5	499	<0.1	0
14	Yamuna Pd. Adhikari	9295	7-20	30/04/2079	30.8	1	7.3	<5	659	<0.1	0
15	Ramakant Sharma	623	8-A2	24/04/2079	30.4	1	7.1	<5	358	<0.1	0
16	Sumitra Rana	14200	9-08	30/04/2079	31.0	1	7.6	<5	526	<0.1	0
17	Chuma Dutta Suvedi	11930	9-17	30/04/2079	30.6	1	7.3	<5	692	<0.1	0
18	Puspa Raj Sappkota	1380	10-1A	24/04/2079	28.6	1	8.0	<5	425	<0.1	0
19	Diwakar Lamichane	10770	10-02	30/04/2079	31.2	1	7.3	<5	639	<0.1	0
20	Bed Maya giri	13210	10-6A	30/04/2079	32.0	1	7.3	<5	689	<0.1	0
21	Gadesh Paudel	4170	10-12	24/04/2079	32.4	1	7.5	<5	698	<0.1	0
22	Khim maya Baral	16688	7-16	24/04/2079	32.9	1	7.9	<5	431	<0.1	0
23	Durga Maya Pradhan	6663	10-15	24/04/2079	29.8	2	8.0	<5	425	0.1	0
24	Mallab Miya	3325	11-16	24/04/2079	31.8	1	7.8	<5	429	<0.1	0
25	Shalik Ram Paudel	12700	12-19	24/04/2079	33.3	1	7.7	<5	466	<0.1	0
26	Hemlal Dahal	15604	10-16	24/04/2079	32.4	1	7.7	<5	473	<0.1	0
27	ward no 12 kayalaya	33210	12-5	24/04/2079	31.9	1	7.8	<5	263	<0.1	0
28	Mina Kumari Paudel	13810	14-25	30/04/2079	31.1	1	7.9	<5	261	<0.1	0
29	Goma Thapa Chhetri	13165	14-25	30/04/2079	31.0	1	8.1	<5	287	<0.1	0
30	Gopal Prasad Kandel	5800	8-12	30/04/2079	32.1	1	7.6	<5	456	<0.1	0
31	Blank			24/04/2079							0
32	Contaminated Water with Cowdung			24/04/2079							>50

* These values show lower and Upper Limits

Tested By: Ram Krishna Khatri

Cheritra

General administration
 By: Sarita Baral


Approved By: Prajapatai
