



Bharatpur Water Supply Management Board
Bharatpur, Chitwan
Drinking Water Quality Test Report of Randomly Selected Customers Baisakh 2082

S. N	Name of Source		Customer ID	Ward Zone	Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Max. Concent. Limits, as per NDWQS-->											
1	Ramesh Kumar Karki	10281	1	18	25/01/2082	30.5	2	7.6	<5	N.O	612	<0.1	0
2	Purna Bahadur Shrestha	5401891	2	6B	25/01/2082	30.9	3	7.0	<5	N.O	398	<0.1	0
3	Prakash Gurung	54011847	2	4	25/01/2082	30.9	2	7.5	<5	N.O	638	<0.1	0
4	Buddhi Bahadur Bhandari	5406164	2	11	25/01/2082	30.8	2	7.7	<5	N.O	550	<0.1	0
5	Ramakanta Sharma	623	2	8A	25/01/2082	30.6	2	6.9	<5	N.O	380	<0.1	0
6	Radha Krishna Shrestha	7925	2	1A	25/01/2082	30.6	2	7.6	<5	N.O	539	<0.1	0
7	Satya Shai Sewa Kendra, Narayanghat	32398	3	9	25/01/2082	30.4	2	7.5	<5	N.O	604	<0.1	0
8	Kopila Kandel	54036465	3	4	25/01/2082	30.4	2	7.6	<5	N.O	580	<0.1	0
9	Buddha Nath Gautam	54017671	3	12	25/01/2082	29.7	2	7.5	<5	N.O	566	<0.1	0
10	Nilkanta Sharma Niure	54014351	3	10	25/01/2082	29.9	2	7.6	<5	N.O	544	<0.1	0
11	Bin Maya Gurung	5408616	4	15	26/01/2082	30.8	2	7.8	<5	N.O	414	<0.1	0
12	Prem Bahadur Chokhal	54020473	4	6	26/01/2082	30.0	2	7.8	<5	N.O	467	<0.1	0
13	Basanta Sapkota	54025745	4	16N	26/01/2082	29.5	2	7.8	<5	N.O	411	<0.1	0
14	Ward No 4 Wada Karyalya	54012999	4	20	26/01/2082	30.8	1	7.8	<5	N.O	413	<0.1	0
15	Bishnu Kumar Kunwar	54028296	5	5	22/01/2082	29.4	2	7.9	<5	N.O	279	<0.1	0
16	Rose Garden Public Bhawan	54019880	5	19	22/01/2082	29.6	2	7.7	<5	N.O	334	<0.1	0
17	Hima Adhikari	54039097	5	5	22/01/2082	29.9	1	7.9	<5	N.O	214	<0.1	0
18	Saroj Ghimire	54041248	5	25	22/01/2082	29.7	2	8.0	<5	N.O	311	<0.1	0
19	War No 6 Ward Office	54037750	6	15	28/01/2082	30.8	2	8.0	<5	N.O	229	<0.1	0
20	Sushree Mamata Sharma	54028888	6	1	26/01/2082	30.6	1	7.8	<5	N.O	430	<0.1	0
21	Pashupati Adhikari	54037915	6	0	28/01/2082	30.7	1	8.1	<5	N.O	286	<0.1	0
22	Jhabiswor Dhakal	5409606	7	16	26/01/2082	31.1	2	7.9	<5	N.O	420	<0.1	0
23	Durga Bahadur Thapa Samet	54015405	7	3	25/01/2082	31.3	2	8.0	<5	N.O	314	<0.1	0
24	Tribikram Thapa Chhetri	54015070	7	14,1	25/01/2082	31.6	3	7.5	<5	N.O	448	<0.1	0
25	Chetana Village	54017018	7	16	25/01/2082	31.0	2	7.9	<5	N.O	439	<0.1	0
26	Sanadial Shrestha	54025862	8	8	25/01/2082	30.9	2	7.9	<5	N.O	448	<0.1	0
27	Harishchandra Ghimire	54011604	8	10	26/01/2082	31.0	2	7.7	<5	N.O	503	<0.1	0
28	Sangita Poudel	54023006	8	16	26/01/2082	30.8	2	8.1	<5	N.O	314	<0.1	0
29	Mahaendra Lal Shrestha	5409075	8	14	26/01/2082	30.7	1	7.9	<5	N.O	328	<0.1	0
30	Buddhi Prasad Sapkota	5405571	9	13	26/01/2082	30.7	2	7.6	<5	N.O	541	<0.1	0
31	Chandradevi Sapkota	54028400	9	19	26/01/2082	30.4	1	8.0	<5	N.O	313	<0.1	0
32	Hema Lama Balampaki	54041442	9	21	26/01/2082	30.3	1	8.2	<5	N.O	307	<0.1	0
33	Chandra Kumari Jarga	54033810	9	29	26/01/2082	30.0	1	8.0	<5	N.O	312	<0.1	0
34	Goushuba Gurung	29277	10	18B	22/01/2082	29.7	2	7.6	<5	N.O	564	<0.1	0
35	Uddhav Bista	540142830	10	21B	22/01/2082	29.5	2	7.5	<5	N.O	535	<0.1	0
36	Netra Kala Regmi	54016782	10	6	22/01/2082	29.5	3	7.8	<5	N.O	498	<0.1	0
37	Nepal Electricity Authority	54013247	10	26B	25/01/2082	29.4	2	7.6	<5	N.O	567	<0.1	0
38	Bhumi Sara Bhurtel	10993	10	3A	26/01/2082	28.9	2	7.7	<5	N.O	537	<0.1	0
39	Jamuna Koirala	9763	11	8	22/01/2082	28.3	2	7.8	<5	N.O	462	<0.1	0
40	Bha.Ma.Na.Pa.11 Ward	54023213	11	12	25/01/2082	29.5	2	7.5	<5	N.O	367	<0.1	0
41	Sumitra Rokka	54036707	11	18A	25/01/2082	28.7	2	8.0	<5	N.O	255	<0.1	0

Executive Director
Joffa

Chemist
[Signature]

42	Kamala Devi Khadka	54010281	12	24	28/01/2082	27.3	1	7.5	<5	N O	347	<0.1	0
43	Shantik Ram Poudel	12700	12	21	25/01/2082	28.7	2	7.8	<5	N O	438	<0.1	0
44	Bimala Devi Neupane	54018238	12	4	22/01/2082	28.7	2	8.0	<5	N O	256	<0.1	0
45	Amudii Foods Pvt. Ltd.	54022667	12	4	22/01/2082	28.8	2	8.0	<5	N O	255	<0.1	0
46	Narayan Prasad Adhikari	54034542	12	23	28/01/2082	29.0	1	7.9	<5	N O	275	<0.1	0
47	Jayram Giri	54041314	13	1	28/01/2082	30.1	2	7.9	<5	N O	286	<0.1	0
48	Bir Bahadur Magar	54041226	13	1	28/01/2082	30.9	2	8.0	<5	N O	269	<0.1	0
49	Bhawana Pokhrel	54040583	13	1	28/01/2082	31.1	2	7.2	<5	N O	404	<0.1	0
50	Buddhiram Mahato	54040052	14	1	28/01/2082	31.2	2	8.0	<5	N O	249	<0.1	0
51	Netra Prasad Adhikari	54025582	14	1	28/01/2082	30.9	1	8.0	<5	N O	247	<0.1	0
52	Shambhu Mahato	54039115	14	1	28/01/2082	30.8	1	7.9	<5	N O	285	<0.1	0
53	Dhurba Raj Poudel	54036968	15	1N	22/01/2082	29.6	1	7.6	<5	N O	333	<0.1	0
54	Binod Prasad Sharma	54032942	15	1	22/01/2082	29.6	1	7.9	<5	N O	315	<0.1	0
55	Sabitri Kandel	54031959	15	10	22/01/2082	29.5	1	7.8	<5	N O	332	<0.1	0
56	Bharatpur Mahanagarपालिका-16	54026293	16	1	22/01/2082	29.6	1	7.9	<5	N O	326	<0.1	0
57	Chandra Prakash Paudel	54039375	16	1	22/01/2082	29.5	1	7.8	<5	N O	331	<0.1	0
58	Nar Bahadur Gurung	54038247	16	0	22/01/2082	29.3	2	7.9	<5	N O	248	<0.1	0
59	Ramlal Mahato	54022975	22	1	28/01/2082	30.9	2	8.0	<5	N O	247	<0.1	0
60	Balram Poudel	54022968	22	1	28/01/2082	30.9	1	8.1	<5	N O	247	<0.1	0
61	Contaminated Water with Cowdung				22/01/2082								>50

* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Checked By
Ramy Krishna Khanal

Chemist

Verified By
Sanjay Baral

Executive Director