


Bharatpur Water Supply Management Board
Bharatpur, Chitwan
Drinking Water Quality Test Report of Randomly Selected Customers, Jestha 2082



S. N	Name of Source	Customer ID	Ward	Zone	Max. Concent. Limits, as per NDVQS-->	Temp. °C	S(10)	pH 6.5 to 8.5*	Colour (TCU) S(15)	Taste and Odor Non objectionable	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
1													
2	Customer Name	Customer ID	Ward	Zone	Max. Concent. Limits, as per NDVQS-->	Temp. °C	S(10)	pH 6.5 to 8.5*	Colour (TCU) S(15)	Taste and Odor Non objectionable	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
3	Ramesh Kumar Karli	10281	1	18	26/02/2082	31.5	1	7.6	<5	NO	609	<0.1	0
4	Purna Bahadur Shrestha	5401891	2	6B	26/02/2082	31.7	1	6.6	<5	NO	247	<0.1	0
5	Prakash Gurung	54011847	2	4	26/02/2082	31.9	1	7.7	<5	NO	576	<0.1	0
6	Buddhi Bahadur Bhandari	5406164	2	11	26/02/2082	31.7	1	7.7	<5	NO	543	<0.1	0
7	Ramakanta Sharma	623	2	8A	26/02/2082	31.6	1	6.9	<5	NO	311	<0.1	0
8	Radha Krishna Shrestha	7925	2	1A	26/02/2082	31.5	1	7.6	<5	NO	559	<0.1	0
9	Saiya Shai Seva Kendra, Narayanghat	32398	3	9	26/02/2082	31.6	1	7.6	<5	NO	625	<0.1	0
10	Kopila Kandel	54036465	3	4	26/02/2082	31.3	1	7.6	<5	NO	581	<0.1	0
11	Boddha Nath Gautam	54017671	3	12	26/02/2082	31.2	1	7.7	<5	NO	378	<0.1	0
12	Nilkantha Sharma Nure	54014351	3	10	26/02/2082	31.2	1	7.6	<5	NO	654	<0.1	0
13	Bin Maya Gurung	5408616	4	15	23/02/2082	28.9	2	7.8	<5	NO	413	<0.1	0
14	Prem Bahadur Chokhal	54020473	4	6	23/02/2082	29.8	1	7.9	<5	NO	416	<0.1	0
15	Basanta Sapkota	54025745	4	16N	23/02/2082	29.1	1	7.8	<5	NO	440	<0.1	0
16	Ward No 4 Wada Kanyalya	54012999	4	20	23/02/2082	30.0	1	7.7	<5	NO	417	<0.1	0
17	Bishnu Kumar Kunwar	54028296	5	5	19/02/2082	29.8	2	8.0	<5	NO	213	<0.1	10
18	Repeated Sample				21/02/2082								0
19	Rose Garden Public Bhawan	54019880	5	19	21/02/2082	29.7	1	7.7	<5	NO	329	<0.1	0
20	Hina Adhikari	54039097	5	5	19/02/2082	29.7	1	8.0	<5	NO	213	<0.1	0
21	Sarfo Ghimire	54041248	5	25	19/02/2082	29.9	2	8.0	<5	NO	275	<0.1	0
22	War No.6 Ward Office	54037750	6	15	21/02/2082	29.6	1	8.0	<5	NO	239	<0.1	0
23	Sushree Manana Sharma	54028888	6	1	23/02/2082	29.6	1	8.1	<5	NO	312	<0.1	0
24	Pashupati Adhikari	54037915	6	0	21/02/2082	29.6	1	8.1	<5	NO	283	<0.1	0
25	Jhabiswor Dhakal	5409606	7	16	23/02/2082	29.5	1	8.1	<5	NO	312	<0.1	0
26	Durga Bahadur Thapa Samet	54015405	7	3	23/02/2082	29.4	1	7.8	<5	NO	416	<0.1	0
27	Tribikram Thapa Chhetri	54015070	7	14.1	23/02/2082	29.4	1	7.8	<5	NO	450	<0.1	0
28	Chetana Village	54017018	7	16	23/02/2082	29.5	1	7.9	<5	NO	418	<0.1	0
29	Samadial Shrestha	54025862	8	8	23/02/2082	29.4	1	7.8	<5	NO	417	<0.1	0
30	Harsichandra Ghimire	5401904	8	10	23/02/2082	29.5	1	8.0	<5	NO	313	<0.1	0
31	Sangita Poudel	54023006	8	16	23/02/2082	29.6	1	8.0	<5	NO	313	<0.1	0
32	Mahaendra Lal Shrestha	5409075	8	14	23/02/2082	29.4	1	7.9	<5	NO	333	<0.1	0
33	Buddhi Prasad Sapkota	5405571	9	13	23/02/2082	29.4	1	7.8	<5	NO	353	<0.1	0
34	Chandradevi Sapkota	54028400	9	19	23/02/2082	29.4	1	8.0	<5	NO	312	<0.1	0
35	Hema Lama Balamkali	54041442	9	21	23/02/2082	29.3	1	7.8	<5	NO	418	<0.1	0
36	Chandra Kumari Janga	54033810	9	29	23/02/2082	29.4	1	8.0	<5	NO	312	<0.1	0
37	Goushaha Gurung	29277	10	18B	19/02/2082	31.4	1	7.6	<5	NO	569	<0.1	0
38	Uddhav Bista	540142830	10	21B	19/02/2082	31.4	1	7.7	<5	NO	431	<0.1	0
39	Netra Kala Regmi	54016782	10	6	19/02/2082	31.5	1	7.6	<5	NO	568	<0.1	0
40	Nepal Electricity Authority	54013247	10	26B	19/02/2082	30.4	1	7.5	<5	NO	571	<0.1	0
40	Bhumi Sara Bhurral	10993	10	3A	26/02/2082	31.1	1	7.6	<5	NO	566	<0.1	0

[Signature]
Chemist

[Signature]
Executive Director



41	Jamuna Koirala	9763	11	8	19/02/2082	29.6	2	7.8	<5	N.O.	438	<0.1	0
42	Bha.Ma.Na.Pa.11 Ward	54023213	11	12	26/02/2082	31.4	1	7.5	<5	N.O.	375	<0.1	0
43	Sumitra Rokka	54036707	11	18A	26/02/2082	31.4	1	7.9	<5	N.O.	259	<0.1	0
44	Narendra Gurung	37251	11	25	26/02/2082	31.3	1	7.4	<5	N.O.	367	<0.1	0
45	Shalik Ram Poudel	12700	12	21	19/02/208	30.3	2	7.7	<5	N.O.	439	<0.1	0
46	Bimala Devi Neupane	54018238	12	4	19/02/208	30.1	1	7.9	<5	N.O.	295	<0.1	0
47	Amudi Foods Pvt. Ltd.	54022667	12	4	19/02/208	30.5	1	8.0	<5	N.O.	259	<0.1	0
48	Narayan Prasad Adhikari	54034542	12	23	19/02/208	29.8	1	7.9	<5	N.O.	268	<0.1	0
49	Jayram Giri	54041314	13	1	21/02/208	29.6	1	8.0	<5	N.O.	264	<0.1	0
50	Bit Bahadur Magar	54041226	13	1	21/02/208	29.7	1	8.0	<5	N.O.	263	<0.1	0
51	Bhawana Pokhrel	54040583	13	1	21/02/208	29.5	1	8.0	<5	N.O.	283	<0.1	0
52	Buddhiram Mahato	54040052	14	1	21/02/208	29.5	1	8.0	<5	N.O.	270	<0.1	0
53	Netra Prasad Adhikari	54025582	14	1	21/02/208	29.4	1	8.0	<5	N.O.	248	<0.1	0
54	Shambhu Mahato	54039115	14	1	21/02/208	29.3	1	8.0	<5	N.O.	283	<0.1	0
55	Dhurba Raj Poudel	54036968	15	IN	19/02/208	29.9	1	7.8	<5	N.O.	222	<0.1	0
56	Binod Prasad Sharma	54032942	15	1	19/02/208	29.9	1	7.8	<5	N.O.	346	<0.1	0
57	Sabitri Kandel	54031959	15	10	19/02/208	30.0	1	7.9	<5	N.O.	333	<0.1	0
58	Bharatpur Mahanagarpalika-16	54026293	16	1	19/02/208	30.0	1	7.8	<5	N.O.	333	<0.1	0
59	Chandra Prakash Paudel	54039375	16	1	19/02/208	29.8	1	7.9	<5	N.O.	333	<0.1	0
60	Nar Bahadur Gurung	54038247	16	0	19/02/208	29.8	1	7.8	<5	N.O.	333	<0.1	0
61	Ramial Mahato	54022975	22	1	21/02/208	29.3	1	8.0	<5	N.O.	247	<0.1	0
	Balram Poudel	54022968	22	1	21/02/208	29.2	1	8.1	<5	N.O.	247	<0.1	0
	Contaminated Water with Cowdung				19/02/2082								>50

* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Checked By
Ram Krishna Choudhary

Approved By
Sanjay Baral
Executive Director