



Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers, Aashadh 2082

Customer Name	Name of Source		Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer ID	Ward									
			Max. Concent. Limits, as per NDWQS-->	°C	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
Ramesh Kumar Karki	10281	1	22/03/2082	30.0	2	7.6	<5	N O	673	<0.1	0
Purna Bahadur Shrestha	5401891	2	19/03/2082	29.8	2	6.8	<5	N O	321	<0.1	0
Prakash Gurung	54011847	2	22/03/2082	30.7	2	7.6	<5	N O	581	<0.1	0
Buddhi Bahadur Bhandari	5406164	2	19/03/2082	29.8	2	7.6	<5	N O	545	<0.1	0
Ramakanta Sharma	623	2	19/03/2082	29.5	2	7.0	<5	N O	304	<0.1	0
Radha Krishna Shrestha	7925	2	19/03/2082	29.6	2	7.7	<5	N O	540	<0.1	0
Satya Shai Sewa Kendra, Narayanghat	32398	3	22/03/2082	30.6	3	7.6	<5	N O	683	<0.1	0
Kopila Kandel	54036465	3	22/03/2082	30.0	3	7.6	<5	N O	562	<0.1	0
Bodha Nath Gautam	54017671	3	22/03/2082	30.0	3	7.6	<5	N O	529	<0.1	0
Nilkantha Sharma Niure	54014351	3	22/03/2082	29.9	2	7.6	<5	N O	536	<0.1	0
Bin Maya Gurung	5408616	4	24/03/2082	31.2	3	7.8	<5	N O	421	<0.1	0
Prem Bahadur Chokhal	54020473	4	24/03/2082	31.4	3	7.8	<5	N O	417	<0.1	0
Basanta Sapkota	54025745	4	24/03/2082	31.4	3	7.9	<5	N O	441	<0.1	2
Repeated Sample			27/03/2082								0
Ward No 4 Wada Karyalya	54012999	4	24/03/2082	31.4	3	7.7	<5	N O	419	<0.1	0
Bishnu Kumar Kunwar	54028296	5	18/03/2082	30.3	1	8.0	<5	N O	213	<0.1	0
Rose Garden Public Bhawan	54019880	5	18/03/2082	30.3	2	7.8	<5	N O	331	<0.1	0
Hima Adhikari	54039097	5	18/03/2082	30.2	1	7.9	<5	N O	213	<0.1	0
Saroj Chimire	54041248	5	18/03/2082	30.3	1	7.9	<5	N O	280	<0.1	0
War No 6 Ward Office	54037750	6	22/03/2082	31.2	2	8.1	<5	N O	231	<0.1	0
Sushree Mamata Sharma	54028888	6	24/03/2082	31.3	3	7.8	<5	N O	418	<0.1	0
Pashupati Adhikari	54037915	6	22/03/2082	31.2	2	8.1	<5	N O	286	<0.1	4
Repeated Sample			27/03/2082								0
Jhabiswor Dhakal	5409606	7	24/03/2082	31.2	3	7.8	<5	N O	421	<0.1	0
Durga Bahadur Thapa Samet	54015405	7	24/03/2082	30.9	3	8.0	<5	N O	315	<0.1	0
Tribikram Thapa Chhetri	54015070	7	24/03/2082	31.0	3	7.6	<5	N O	478	<0.1	0
Chetana Village	54017018	7	24/03/2082	30.9	3	8.0	<5	N O	452	<0.1	0
Samadial Shrestha	54025862	8	24/03/2082	30.9	3	7.8	<5	N O	417	<0.1	0
Harishchandra Ghimire	54011604	8	24/03/2082	30.9	3	7.8	<5	N O	418	<0.1	0
Sangita Poudel	54023006	8	24/03/2082	30.9	2	7.9	<5	N O	415	<0.1	0
Mahaendra Lal Shrestha	5409075	8	24/03/2082	30.9	3	7.8	<5	N O	458	<0.1	0
Buddhi Prasad Sapkota	5405571	9	24/03/2082	30.9	3	7.8	<5	N O	423	<0.1	0

Executive Director

Chemist

1	Chandradevi Sapkota	54028400	9	19	24/03/2082	30.8	3	7.8	<5	N O	415	<0.1	0
32	Hema Lama Balampaki	54041442	9	21	24/03/2082	30.6	3	7.9	<5	N O	416	<0.1	0
33	Chandra Kumari Jarga	54033810	9	29	24/03/2082	30.6	3	7.8	<5	N O	416	<0.1	0
34	Goushuba Gurung	29277	10	18 B	25/03/2082	28.7	3	7.6	<5	N O	663	<0.1	0
5	Uddhav Bista	540142830	10	21B	19/03/2082	29.7	2	7.7	<5	N O	521	<0.1	0
6	Netra Kala Regmi	54016782	10	6	19/03/2082	30.5	2	7.6	<5	N O	667	<0.1	0
7	Nepal Electricity Authority	54013247	10	26B	19/03/2082	30.1	2	7.5	<5	N O	558	<0.1	0
8	Bhumi Sara Bhurtel	10993	10	3A	22/03/2082	29.9	3	7.7	<5	N O	559	<0.1	0
9	Jamuna Koirala	9763	11	8	25/03/2082	29.5	3	7.7	<5	N O	534	<0.1	0
0	Bha.Ma.Na.Pa.11 Ward	54023213	11	12	22/03/2082	30.4	2	7.4	<5	N O	375	<0.1	0
1	Sumitra Rokka	54036707	11	18A	25/03/2082	29.8	3	8.0	<5	N O	268	<0.1	0
3	Shalik Ram Poudel	12700	12	21	25/03/2082	30.7	2	7.6	<5	N O	492	<0.1	0
4	Bimala Devi Neupane	54018238	12	4	25/03/2082	30.1	3	8.0	<5	N O	267	<0.1	0
5	Amadi Foods Pvt. Ltd.	54022667	12	4	19/03/2082	30.3	2	8.0	<5	N O	268	<0.1	0
6	Narayan Prasad Adhikari	54034542	12	23	25/03/2082	29.7	2	7.1	<5	N O	358	<0.1	0
7	Jayram Giri	54041314	13	1	22/03/2082	31.2	1	7.9	<5	N O	287	<0.1	0
8	Bir Bahadur Magar	54041226	13	1	22/03/2082	31.3	2	8.0	<5	N O	268	<0.1	0
9	Bhawana Pokhrel	54040583	13	1	22/03/2082	31.3	2	7.9	<5	N O	283	<0.1	0
0	Buddhiram Mahato	54040052	14	1	22/03/2082	31.1	2	8.0	<5	N O	285	<0.1	0
1	Netra Prasad Adhikari	54025582	14	1	22/03/2082	31.0	2	8.0	<5	N O	250	<0.1	0
2	Shambhu Mahato	54039115	14	1	22/03/2082	30.8	2	8.0	<5	N O	245	<0.1	0
3	Dhurba Raj Poudel	54036968	15	1N	18/03/2082	30.3	1	7.7	<5	N O	219	<0.1	0
4	Binod Prasad Sharma	54032942	15	1	18/03/2082	30.1	1	7.9	<5	N O	307	<0.1	0
5	Sabitri Kandel	54031959	15	10	18/03/2082	30.0	1	7.9	<5	N O	310	<0.1	0
6	Bharatpur Mahanagarपालिका-16	54026293	16	1	18/03/2082	29.8	1	7.8	<5	N O	322	<0.1	0
7	Chandra Prakash Paudel	54039375	16	1	18/03/2082	29.9	1	7.9	<5	N O	320	<0.1	0
8	Nar Bahadur Gurung	54038247	16	0	18/03/2082	29.7	1	7.8	<5	N O	332	<0.1	0
9	Ramlal Mahato	5402975	22	1	22/03/2082	30.8	2	8.1	<5	N O	250	<0.1	0
0	Balram Poudel	54022968	22	1	22/03/2082	30.7	3	8.1	<5	N O	250	<0.1	2
51	Contaminated Water with Cowdung				27/03/2082								>50

* These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.

Verified By
Sanjay Baral

Executive Director

Checked By
Ram Krishna Khanal

Chemist