

**Bihar State Water Supply Corporation Limited**Bihar State Water Supply Corporation Limited
Drinking Water Quality Test Report for Customers Bhadrā 2082


Customer Name	Name of Source		Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer ID	Ward									
			Max. Concent. Limits, as per NDWQS→	°C	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
Ramesh Kumar Karki	10281	1	29/05/2082	27.5	2	7.6	<5	N.O	668	<0.1	0
Purna Bahadur Shrestha	5401891	2	30/05/2082	28.1	2	6.8	<5	N.O	285	<0.1	0
Prakash Gurung	54011847	2	30/05/2082	27.5	1	7.5	<5	N.O	585	<0.1	0
Buddhi Bahadur Bhandari	5406164	2	30/05/2082	27.7	1	7.6	<5	N.O	589	<0.1	0
Ramakanta Sharma	623	2	30/05/2082	27.5	1	7.5	<5	N.O	572	<0.1	0
Radha Krishna Shrestha	7925	2	30/05/2082	27.5	1	7.6	<5	N.O	577	<0.1	0
Atya Shai Sewa Kendra, Narayanghat	32398	3	30/05/2082	27.8	1	7.5	<5	N.O	666	<0.1	0
Kopila Kandel	54036465	3	30/05/2082	27.6	1	7.6	<5	N.O	556	<0.1	0
Boddha Nath Gautam	54017671	3	30/05/2082	28.1	1	7.6	<5	N.O	526	<0.1	0
Nilkantha Sharma Niure	54014351	3	30/05/2082	27.8	1	7.6	<5	N.O	523	<0.1	0
Bin Maya Gurung	5408616	4	30/05/2082	28.2	2	7.8	<5	N.O	432	<0.1	0
Prem Bahadur Chokhal	54020473	4	30/05/2082	28.3	2	7.9	<5	N.O	429	<0.1	0
Basanta Sapkota	54025745	4	30/05/2082	28.3	1	7.9	<5	N.O	435	<0.1	0
Ward No 4 Wada Karyalya	54012999	4	30/05/2082	28.3	1	7.8	<5	N.O	427	<0.1	0
Bishnu Kumar Kunwar	54028296	5	29/05/2082	28.4	1	8.0	<5	N.O	223	<0.1	0
Rose Garden Public Bhawan	54019880	5	29/05/2082	28.3	2	7.7	<5	N.O	339	<0.1	0
Hima Adhikari	54039097	5	29/05/2082	28.3	1	7.9	<5	N.O	213	<0.1	0
Saroj Ghimire	54041248	5	29/05/2082	28.1	1	8.0	<5	N.O	279	<0.1	0
War No 6 Ward Office	54037750	6	18/05/2082	30.7	1	8.1	<5	N.O	231	<0.1	0
Sushree Mamata Sharma	54028888	6	30/05/2082	28.4	1	8.1	<5	N.O	308	<0.1	0
Pashupati Adhikari	54037915	6	18/05/2082	30.6	1	8.1	<5	N.O	283	<0.1	0
Jhabiswor Dhakal	5409606	7	30/05/2082	28.1	1	7.8	<5	N.O	422	<0.1	0
Durga Bahadur Thapa Samet	54015405	7	30/05/2082	28.2	1	8.1	<5	N.O	308	<0.1	0
Tribikram Thapa Chhetri	54015070	7	30/05/2082	28.2	1	8.1	<5	N.O	308	<0.1	0
Chetana Village	54017018	7	30/05/2082	28.2	1	8.1	<5	N.O	453	<0.1	0
Sanaadal Shrestha	54025862	8	30/05/2082	28.4	2	7.7	<5	N.O	422	<0.1	0
Harishchandra Ghimire	54011604	8	30/05/2082	28.3	1	7.9	<5	N.O	315	<0.1	0
Sangita Poudel	54023006	8	30/05/2082	28.1	1	8.0	<5	N.O	307	<0.1	0
Mahaendra Lal Shrestha	5409075	8	30/05/2082	28.3	1	7.7	<5	N.O	507	<0.1	0
Buddhi Prasad Sapkota	5405571	9	30/05/2082	28.2	1	7.7	<5	N.O	478	<0.1	0
Chandradevi Sapkota	54028400	9	30/05/2082	28.5	1	7.9	<5	N.O	449	<0.1	0
Hema Lama Balampaki	54041442	9	30/05/2082	28.3	1	7.8	<5	N.O	419	<0.1	0

Executive Director
*[Signature]*Chemist
[Signature]

Chandra Kumari Jarga	54033810	9	29	30/05/2082	28.1	1	7.7	<5	N O	450	<0.1	0
Goushuba Gurung	29277	10	18 B	18/05/2082	29.9	1	7.5	<5	N O	584	<0.1	0
Uddhav Bista	540142830	10	21B	18/05/2082	29.6	1	7.7	<5	N O	514	<0.1	0
Netra Kala Regmi	54016782	10	6	18/05/2082	29.9	1	7.6	<5	N O	664	<0.1	0
Nepal Electricity Authority	54013247	10	26B	30/05/2082	28.2	1	7.6	<5	N O	552	<0.1	0
Bhumi Sara Bhurtel	10993	10	3A	30/05/2082	27.6	1	7.7	<5	N O	549	<0.1	0
Jamuna Koirala	9763	11	8	18/0/2082	29.3	1	7.8	<5	N O	468	<0.1	0
Bha.Ma.Na.Pa.11 Ward	54023213	11	12	30/05/2082	28.1	1	7.5	<5	N O	377	<0.1	0
Sumitra Rokka	54036707	11	18A	18/05/2082	29.7	1	7.7	<5	N O	264	<0.1	0
Narendra Gurung	54037251	11	25	30/05/2082	28.3	1	7.6	<5	N O	378	<0.1	0
Shalik Ram Poudel	12700/690	12	21	18/05/2082	30.1	1	7.7	<5	N O	473	<0.1	0
Bimala Devi Neupane	54018238	12	4	18/05/2082	29.6	1	8.0	<5	N O	264	<0.1	0
Amudi Foods Pvt. Ltd.	54022667	12	4	18/05/2082	29.6	1	8.1	<5	N O	264	<0.1	0
Narayan Prasad Adhikari	54034542	12	23	18/05/2082	29.7	1	7.8	<5	N O	260	<0.1	0
Jayram Giri	54041314	13	1	18/05/2082	30.5	1	7.8	<5	N O	284	<0.1	0
Bir Bahadur Magar	54041226	13	1	18/05/2082	30.6	1	8.1	<5	N O	267	<0.1	0
Bhawana Pokhrel	54040583	13	1	18/05/2082	30.6	1	8.1	<5	N O	282	<0.1	0
Buddhiram Mahato	54040052	14	1	18/05/2082	30.5	1	8.0	<5	N O	249	<0.1	0
Netra Prasad Adhikari	54025582	14	1	18/05/2082	30.4	1	8.0	<5	N O	257	<0.1	0
Shambhu Mahato	54039115	14	1	18/05/2082	30.3	1	8.0	<5	N O	247	<0.1	0
Dhurba Raj Poudel	54036968	15	1N	18/05/2082	30.2	2	8.0	<5	N O	257	<0.1	0
Binoo Prasad Sharma	54032942	15	1	29/05/2082	28.5	1	7.9	<5	N O	305	<0.1	0
Sabitri Kandel	54031959	15	10	29/05/2082	28.5	1	7.9	<5	N O	307	<0.1	0
Bharatpur Mahanagarपालिका-16	54026293	16	1	29/05/2082	28.1	1	7.9	<5	N O	309	<0.1	0
Chandra Prakash Paudel	54039375	16	1	29/05/2082	28.2	1	7.9	<5	N O	305	<0.1	0
Nar Bahadur Gurung	54038247	16	0	29/05/2082	28.2	1	7.8	<5	N O	331	<0.1	0
Ramlal Mahato	54022975	22	1	18/05/2082	30.3	1	8.0	<5	N O	257	<0.1	0
Balram Poudel	54022968	22	1	29/05/2082	28.3	1	7.7	<5	N O	222	<0.1	0
Contaminated Water with Cowdung				18/05/2082								>40

These values show lower and Upper Limits

Result: The tested samples are within the range as per the NDWQS 2079 for drinking water.



Checked By
Rani Krishna Khanal

Chemist

[Signature]

Approved By
Sanjay Baral

Executive Director