




Bhairatpur Water Supply Management Board
 Drinking Water Quality Test Report of Bhairatpur, Nepal, Customers: Ashwin 2082

Customer Name	Customer ID	Ward Zone	Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Total Hardness (mg/L)	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
Ramesh Kumar Karri	10281	1 18	24/06/2082	29.2	2	7.7	<5	N.O	240	582	<0.1	0
Purna Bahadur Shrestha	5401891	2 6B	24/06/2082	28.6	1	6.6	<5	N.O	110	248	<0.1	0
Prakash Gurung	54011847	2 4	24/06/2082	29.1	1	7.5	<5	N.O	250	587	<0.1	0
Buddhi Bahadur Bhandari	5406164	2 11	24/06/2082	29.2	1	7.6	<5	N.O	244	589	<0.1	0
Ramakanta Sharma	623	2 8A	24/06/2082	29.1	1	6.7	<5	N.O	102	254	<0.1	0
Radha Krishna Shrestha	7925	2 1A	24/06/2082	29.0	1	7.6	<5	N.O	230	584	<0.1	0
Shai Seva Kendra, Narayanghat	32398	3 9	24/06/2082	29.0	1	7.6	<5	N.O	270	674	<0.1	0
Kopila Kandel	54036465	3 4	24/06/2082	28.8	1	7.6	<5	N.O	268	596	<0.1	0
Bodha Nath Gautam	54017671	3 12	24/06/2082	28.7	1	7.6	<5	N.O	214	512	<0.1	0
Nilkantha Sharma Niure	54014351	3 10	24/06/2082	29.0	1	7.7	<5	N.O	228	525	<0.1	0
Bin Maya Gurung	5408616	4 15	27/06/2082	26.2	1	7.8	<5	N.O	192	428	<0.1	0
Prem Bahadur Chokhal	54020473	4 6	27/06/2082	25.6	1	7.9	<5	N.O	174	432	<0.1	0
Basanta Sapkota	54025745	4 16N	27/06/2082	25.5	1	8.2	<5	N.O	132	303	<0.1	0
Ward No 4 Wada Karyalya	54012999	4 20	27/06/2082	25.7	1	7.9	<5	N.O	190	430	<0.1	0
Bishnu Kumar Kunwar	54028296	5 5	22/06/2082	28.9	2	7.9	<5	N.O	130	283	<0.1	0
Rose Garden Public Bhawan	54019880	5 19	22/06/2082	28.9	1	7.7	<5	N.O	130	341	<0.1	0
Hima Adhikari	54039097	5 5	22/06/2082	29.0	1	7.8	<5	N.O	264	288	<0.1	0
Saroj Ghimire	54041248	5 25	22/06/2082	29.0	1	8.0	<5	N.O	110	265	<0.1	0
War No 6 Ward Office	54037750	6 15	26/06/2082	28.6	1	8.0	<5	N.O	130	234	<0.1	0
Sushree Mamata Sharma	54028888	6 1	27/06/2082	25.6	1	8.1	<5	N.O	190	416	<0.1	0
Pashupati Adhikari	54037915	6 0	26/06/2082	28.8	2	8.0	<5	N.O	130	281	<0.1	0
Jhaviswor Dhakal	5409606	7 16	27/06/2082	26.0	1	7.8	<5	N.O	210	415	<0.1	0
Purga Bahadur Thapa Samet	54015405	7 3	27/06/2082	25.6	2	8.0	<5	N.O	188	447	<0.1	0
Tribikram Thapa Chhetri	54015070	7 14.1	27/06/2082	25.6	2	8.1	<5	N.O	148	304	<0.1	0
Chetana Village	54017018	7 16	27/06/2082	25.7	2	8.1	<5	N.O	194	451	<0.1	0
-Sanadial Shrestha	54025862	8 8	27/06/2082	25.8	2	8.1	<5	N.O	136	305	<0.1	0
Harishchandra Ghimire	54011604	8 10	27/06/2082	25.6	2	7.9	<5	N.O	200	410	<0.1	0
Sangita Poudel	54023006	8 16	27/06/2082	25.7	2	7.9	<5	N.O	202	415	<0.1	0
Mahendra Lal Shrestha	5409075	8 14	27/06/2082	25.8	1	7.8	<5	N.O	190	422	<0.1	0
Buddhi Prasad Sapkota	5405571	9 13	27/06/2082	25.9	1	8.1	<5	N.O	156	315	<0.1	0
Chandradevi Sapkota	54028400	9 19	27/06/2082	25.9	2	7.9	<5	N.O	198	377	<0.1	0
Hema Lama Balanpaki	54041442	9 21	27/06/2082	26.0	2	7.7	<5	N.O	194	310	<0.1	0
Chandra Kumari Jarga	54033810	9 29	27/06/2082	26.1	2	7.9	<5	N.O	218	407	<0.1	0
Goushaha Gurung	29277	10 18 B	22/06/2082	28.7	1	7.7	<5	N.O	250	563	<0.1	0
Uddhav Bista	5401428/30	10 21B	22/06/2082	28.7	1	7.6	<5	N.O	210	485	<0.1	0
Netra Kala Regmi	54016782	10 6	22/06/2082	28.6	1	7.7	<5	N.O	220	520	<0.1	0
Nepal Electricity Authority	54013247	10 26B	22/06/2082	28.6	1	7.6	<5	N.O	230	564	<0.1	0
Bhumi Sara Bhuurtel	10993	10 3A	24/06/2082	28.8	1	7.6	<5	N.O	202	519	<0.1	0
Jamuna Koirala	9763	11 8	22/06/2082	28.6	1	6.8	<5	N.O	130	285	<0.1	0
Bha.Ma.Na.Pa.11 Ward	54023213	11 12	24/06/2082	29.0	1	7.5	<5	N.O	170	374	<0.1	0
Sumitra Rokhta	54036707	11 18A	22/06/2082	28.4	1	7.9	<5	N.O	120	273	<0.1	0
Narendra Gurung	54037251	11 25	24/06/2082	28.7	1	7.3	<5	N.O	164	355	<0.1	0
Shalik Ram Poudel	12700/690	12 21	22/06/2082	28.5	1	7.4	<5	N.O	190	428	<0.1	0
Bimala Devi Neupane	54018238	12 4	22/06/2082	28.4	1	8.1	<5	N.O	130	264	<0.1	0
Amudi Foods Pvt. Ltd.	54022667	12 4	22/06/2082	28.3	1	8.1	<5	N.O	130	267	<0.1	0
Narayan Prasad Adhikari	54034542	12 23	22/06/2082	28.2	1	7.5	<5	N.O	170	391	<0.1	0




Executive Director
 [Signature]

Chemist
 [Signature]

7	Jayram Giri	54041314	13	1	26/06/2082	28.7	1	7.8	<5	N O	122	284	<0.1	0
8	Bir Bahadur Magar	54041226	13	1	26/06/2082	28.7	1	8.0	<5	N O	134	265*	<0.1	0
9	Bhawana Pokhrel	54040583	13	1	26/06/2082	28.9	1	8.1	<5	N O	130	280	<0.1	0
10	Buddhiram Mahato	54040052	14	1	26/06/2082	28.9	1	7.9	<5	N O	126	267	<0.1	0
11	Netra Prasad Adhikari	54025582	14	1	26/06/2082	28.7	1	8.1	<5	N O	120	250	<0.1	0
12	Shambhu Mahato	54039115	14	1	26/06/2082	28.7	1	7.9	<5	N O	140	255	<0.1	0
13	Dhurba Raj Poudel	54036968	15	IN	22/06/2082	29.0	1	7.8	<5	N O	90	221	<0.1	0
14	Binod Prasad Sharma	54032942	15	1	22/06/2082	28.7	1	7.9	<5	N O	140	305	<0.1	0
15	Sabitri Kandel	54031959	15	10	22/06/2082	28.6	1	7.9	<5	N O	140	304	<0.1	0
16	Bharatpur Mahanagarpalika-16	54026293	16	1	22/06/2082	28.6	1	7.9	<5	N O	140	305	<0.1	0
17	Chandra Prakash Paudel	54039375	16	1	22/06/2082	28.6	1	7.9	<5	N O	130	305	<0.1	0
18	Nar Bahadur Gurung	54038247	16	0	22/06/2082	28.5	1	7.8	<5	N O	160	332	<0.1	0
19	Ramial Mahato	54022975	22	1	26/06/2082	28.5	1	8.1	<5	N O	130	259	<0.1	0
20	Balram Poudel	54022968	22	1	26/06/2082	28.4	1	8.1	<5	N O	130	253	<0.1	0
21	Contaminated Water with Cowdung				22/06/2082									>50

* These values show lower and Upper Limits

Result: The tested samples have the parameters within the range as per the NDWQS 2079 for drinking water.



Checked By
Ranjana Khatri
Chemist

Signature of Sanjay

Approved By
Sanjay

Executive Director