



Bharatpur Water Supply Management Board
Bharatpur, Chitwan
Drinking Water Quality Test Report of Randomly Selected Customers Mangsir, 2082

S. N	Name of Source		Customer ID	Ward Zone	Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Zone											
1	Ramesh Kumar Karki Repeated Sample	18	10281	1	28/08/2082	20.8	2	7.6	<5	N.O	386	<0.1	>30
2	Purna Bahadur Shrestha Repeated Sample	6B	5401891	2	28/08/2082	21.5	1	6.6	<5	N.O	431	<0.1	>30
3	Prakash Gurung Repeated Sample	4	54011847	2	29/08/2082	21.4	1	7.7	<5	N.O	387	<0.1	12
4	Buddhi Bahadur Bhandari Repeated Sample	11	5406164	2	28/08/2082	21.7	1	7.8	<5	N.O	431	<0.1	12
5	Ramakanta Sharma	8A	623	2	28/08/2082	21.5	1	7.9	<5	N.O	441	<0.1	0
6	Radha Krishna Shrestha	1A	7925	2	28/08/2082	21.6	1	7.8	<5	N.O	442	<0.1	0
7	Satya Shai Sewa Kendra, Narayanghat	9	32398	3	28/08/2082	20.8	1	7.8	<5	N.O	444	<0.1	0
8	Kopila Kandel	3	54036465	4	28/08/2082	21.3	1	7.9	<5	N.O	481	<0.1	0
9	Bodha Nath Gautam	12	54017671	3	28/08/2082	21.0	1	7.8	<5	N.O	443	<0.1	0
10	Nilkantha Sharma Niure Repeated Sample	10	54014351	3	28/08/2082	21.2	1	7.8	<5	N.O	480	<0.1	4
11	Bin Maya Gurung	15	5408616	4	25/08/2082	21.3	2	7.8	<5	N.O	424	<0.1	0
12	Prem Bahadur Chokhal	6	54020473	4	25/08/2082	21.1	2	7.8	<5	N.O	421	<0.1	0
13	Basanta Sapkota	16N	54025745	4	25/08/2082	21.1	2	7.9	<5	N.O	436	<0.1	0
14	Ward No 4 Wada Karyalya	20	54012999	4	25/08/2082	20.8	1	8.5	<5	N.O	405	<0.1	0
15	Bishnu Kumar Kunwar	5	54028296	5	26/08/2082	20.9	1	7.8	<5	N.O	204	<0.1	0
16	Rose Garden Public Bhawan	19	54019880	5	26/08/2082	21.1	2	7.9	<5	N.O	299	<0.1	0
17	Hima Adhikari	5	54039097	5	26/08/2082	21.2	2	8.0	<5	N.O	204	<0.1	0
18	Saroj Ghimire	5	54041248	5	26/08/2082	20.8	1	8.0	<5	N.O	300	<0.1	0
19	War No 6 Ward Office	15	54037750	6	21/08/2082	18.9	2	8.0	<5	N.O	224	<0.1	0
20	Sushree Mamata Sharma	1	54028888	6	25/08/2082	21.5	2	8.0	<5	N.O	301	<0.1	0
21	Pashupati Adhikari	6	54037915	6	21/08/2082	18.9	1	8.1	<5	N.O	268	<0.1	0
22	Jhabiswor Dhakal	16	5409606	7	25/08/2082	21.0	2	7.7	<5	N.O	463	<0.1	0
23	Durga Bahadur Thapa Samet	3	54015405	7	25/08/2082	21.2	2	7.9	<5	N.O	450	<0.1	0
24	Tribikram Thapa Chhetri	14.1	54015070	7	25/08/2082	21.2	2	7.9	<5	N.O	441	<0.1	0
25	Chetana Village	16	54017018	7	25/08/2082	20.9	1	8.1	<5	N.O	444	<0.1	0
26	Sanadlal Shrestha	8	54025862	8	25/08/2082	21.0	2	7.9	<5	N.O	439	<0.1	0
27	Harishchandra Ghimire	10	54011604	8	25/08/2082	21.0	1	7.7	<5	N.O	456	<0.1	0
28	Sangita Poudel	8	54023006	8	25/08/2082	20.9	2	7.8	<5	N.O	425	<0.1	0
29	Mahaendra Lal Shrestha	14	5409075	8	25/08/2082	20.8	1	7.9	<5	N.O	483	<0.1	0
30	Buddhi Prasad Sapkota	13	5405571	9	25/08/2082	20.4	1	8.1	<5	N.O	300	<0.1	0
31	Chandradevi Sapkota	19	54028400	9	25/08/2082	20.8	1	7.8	<5	N.O	425	<0.1	0
32	Hema Lama Balampaki	21	54041442	9	25/08/2082	20.5	1	7.8	<5	N.O	417	<0.1	0
33	Chandra Kumari Jarga	29	54033810	9	25/08/2082	20.6	2	7.7	<5	N.O	418	<0.1	0
34	Goushuba Gurung Repeated Sample	18 B	29277	10	26/08/2082	20.0	1	7.9	<5	N.O	441	<0.1	14
35	Uddhav Bista	10	5401428/30	10	26/08/2082	19.9	1	8.0	<5	N.O	415	<0.1	12

Chemist

Executive Director

[Signature]

