




**Bharatpur Water Supply Management Board**  
Bharatpur, Chitwan District, Nepal  
Drinking Water Quality Test Report of Randomly Selected Customers, March 2082

S. No	Name of Source		Zone	Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID										
1	Ramesh Kumar Karli	10281	1	25/10/2082	21.2	2	7.5	<5	NO	638	<0.1	0
2	Purna Bahadur Shrestha	5401891	2	25/10/2082	21.4	2	6.9	<5	NO	256	<0.1	0
3	Prakash Gurung	54011847	2	25/10/2082	20.2	2	7.4	<5	NO	570	<0.1	0
4	Buddhi Bahadur Bhandari	5406164	2	25/10/2082	21.8	2	7.6	<5	NO	491	<0.1	0
5	Ramakanta Sharma	623	2	25/10/2082	21.6	1	6.8	<5	NO	286	<0.1	0
6	Radha Krishna Shrestha	7925	2	25/10/2082	21.7	2	7.7	<5	NO	492	<0.1	0
7	Satya Shai Sewa Kendra, Narayanghat	32398	3	25/10/2082	21.4	2	7.6	<5	NO	636	<0.1	0
8	Kopila Kandel	54036465	3	25/10/2082	21.2	2	7.6	<5	NO	610	<0.1	0
9	Boddha Nath Gautam	54017671	3	25/10/2082	21.3	2	7.6	<5	NO	548	<0.1	0
10	Nilkantha Sharma Niure	54014351	3	25/10/2082	20.7	2	7.6	<5	NO	543	<0.1	0
11	Bin Maya Gurung	5408616	4	23/10/2082	20.6	1	7.8	<5	NO	418	<0.1	0
12	Prem Bahadur Chokhal	54020473	4	23/10/2082	20.5	2	7.8	<5	NO	414	<0.1	0
13	Basanta Sapkota	54025745	4	23/10/2082	20.7	1	7.8	<5	NO	415	<0.1	0
14	Ward No 4 Wada Karyalya	54012999	4	23/10/2082	20.8	1	7.8	<5	NO	417	<0.1	0
15	Bishnu Kumar Kunwar	54028296	5	21/10/2082	21.5	1	8.0	<5	NO	202	<0.1	0
16	Rose Garden Public Bhawan	54019880	5	21/10/2082	21.9	1	8.1	<5	NO	202	<0.1	0
17	Hima Adhikari	54039097	5	21/10/2082	22.3	1	8.0	<5	NO	260	<0.1	0
18	Saroj Ghimire	54041248	5	21/10/2082	22.3	1	8.0	<5	NO	261	<0.1	0
19	War No 6 Ward Office	54037750	6	26/10/2082	20.1	2	8.1	<5	NO	225	<0.1	0
20	Sushree Mamata Sharma	54028888	6	23/10/2082	20.1	1	8.1	<5	NO	302	<0.1	0
21	Pashupati Adhikari	54037915	6	26/10/2082	19.9	2	8.1	<5	NO	267	<0.1	0
22	Jhabiswor Dhakal	5409606	7	23/10/2082	20.4	2	7.8	<5	NO	422	<0.1	0
23	Durga Bahadur Thapa Samet	54015405	7	23/10/2082	20.2	2	7.9	<5	NO	424	<0.1	0
24	Tribikram Thapa Chhetri	54015070	7	23/10/2082	20.5	1	7.8	<5	NO	433	<0.1	0
25	Chetana Village	54017018	7	23/10/2082	20.7	1	7.8	<5	NO	484	<0.1	0
26	Sanadlal Shrestha	54025862	8	23/10/2082	20.3	1	7.7	<5	NO	415	<0.1	0
27	Harishchandra Ghimire	54011604	8	23/10/2082	20.4	1	7.7	<5	NO	470	<0.1	0
28	Sangita Poudel	54023006	8	23/10/2082	20.6	1	7.8	<5	NO	438	<0.1	0
29	Mahaendra Lal Shrestha	5409075	8	23/10/2082	20.5	1	7.8	<5	NO	420	<0.1	0
30	Buddhi Prasad Sapkota	5405571	9	23/10/2082	20.5	1	7.9	<5	NO	434	<0.1	0
31	Chandra Devi Sapkota	54028400	9	23/10/2082	20.5	1	7.8	<5	NO	436	<0.1	0
32	Hema Lama Balampaki	54041442	9	23/10/2082	20.3	1	7.9	<5	NO	419	<0.1	0
33	Chandra Kumari Jarga	54033810	9	23/10/2082	20.0	1	7.9	<5	NO	425	<0.1	0
34	Goushuba Gurung	29277	10	25/10/2082	21.8	1	7.6	<5	NO	577	<0.1	0
35	Uddhav Bista	540142830	10	21/10/2082	21.8	1	7.7	<5	NO	465	<0.1	0
36	Netra Kala Regmi	54016782	10	25/10/2082	20.6	1	7.7	<5	NO	611	<0.1	0
37	Nepal Electricity Authority	54013247	10	26B	21/10/2082	21.2	1	7.6	<5	567	<0.1	0
38	Bhumi Sara Bhurtel	10993	10	3A	25/10/2082	21.2	1	7.6	<5	530	<0.1	0
39	Jamuna Kohrala	9763	11	8	21/10/2082	21.1	1	7.9	<5	423	<0.1	0
40	Bha.Ma.Na.Pa.II Ward	54023213	11	12	21/10/2082	20.8	2	7.7	<5	354	<0.1	0
41	Sumitra Rokka	54036707	11	18A	21/10/2082	20.8	1	8.1	<5	252	<0.1	0

Executive Director

Chemist



43	Narendra Gurung	54037251	11	25	21/10/2082	20.1	2	7.3	<5	NO	326	<0.1	0
44	Shahik Ram Poudel	12700690	12	21	21/10/2082	20.9	1	7.2	<5	NO	413	<0.1	0
45	Bimala Devi Neupane	54018238	12	4	21/10/2082	20.5	2	8.0	<5	NO	252	<0.1	0
46	Amudi Foods Pvt. Ltd.	54022667	12	4	21/10/2082	21.1	1	8.1	<5	NO	254	<0.1	0
47	Narayan Prasad Adhikari	54034542	12	23	21/10/2082	20.8	1	7.9	<5	NO	353	<0.1	0
48	Jayram Giri	54041314	13	1	26/10/2082	20.1	1	8.1	<5	NO	266	<0.1	0
49	Bir Bahadur Magar	54041226	13	1	26/10/2082	20.0	1	8.1	<5	NO	254	<0.1	0
50	Bhawana Pokhrel	54040583	13	1	26/10/2082	20.0	1	8.2	<5	NO	266	<0.1	0
51	Buddhiram Mahato	54040052	14	1	26/10/2082	19.9	1	8.1	<5	NO	247	<0.1	0
52	Netra Prasad Adhikari	54025582	14	1	26/10/2082	19.9	1	8.2	<5	NO	243	<0.1	0
53	Shambhu Mahato	54039115	14	1	26/10/2082	19.7	1	8.1	<5	NO	247	<0.1	0
54	Dhruva Raj Poudel	54036968	15	1N	21/10/2082	21.0	1	7.9	<5	NO	230	<0.1	0
55	Binod Prasad Sharma	54032942	15	1	21/10/2082	20.9	1	7.9	<5	NO	310	<0.1	0
56	Sabitri Kandel	54031959	15	10	21/10/2082	20.7	1	7.9	<5	NO	295	<0.1	0
57	Bharatpur Mahanagarपालिका-16	54026293	16	1	21/10/2082	20.6	1	7.9	<5	NO	298	<0.1	0
58	Chandra Prakash Paudel	54039375	16	1	21/10/2082	20.5	1	7.9	<5	NO	295	<0.1	0
59	Nar Bahadur Gurung	54038247	16	0	21/10/2082	20.3	1	7.9	<5	NO	295	<0.1	0
60	Ramlal Mahato	54022975	22	1	26/10/2082	19.9	1	8.2	<5	NO	243	<0.1	0
61	Balram Poudel	54022968	22	1	26/10/2082	19.6	1	8.2	<5	NO	253	<0.1	0
	Contaminated Water with Cowdung				21/10/2082								>40

\* These values show lower and Upper Limits

Result: The tested samples have the parameters within the range as per the NDWQS 2079 for drinking water.

Checked By  
Ramy Krishna Khana  
Chemist

Approved By  
Sanjay Baral  
Executive Director