

Bharatpur Water Supply Management Board

Drinking Water Quality Test Report of 1000 Selected Customers, Jashn 2083


S.N	Name of Source		Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID									
1	Ramesh Kumar Karki	10281	1	18	25/02/2083	28.6	2	7.6	<5	N.O	0
2	Purna Bahadur Shrestha	5401891	2	6B	25/02/2083	28.1	1	6.6	<5	N.O	0
3	Prakash Gurung	54011847	2	4	25/02/2083	28.6	1	7.7	<5	N.O	0
4	Buddhi Bahadur Bhandari	5406164	2	11	25/02/2083	28.2	1	7.7	<5	N.O	0
5	Ramakanta Sharma	623	2	8A	25/02/2083	28.0	1	6.7	<5	N.O	0
6	Radhika Krishna Shrestha	7925	2	1A	25/02/2083	28.4	1	7.8	<5	N.O	0
7	Satiya Shal Sewa Kendra, Narayanghat	32398	3	9	25/02/2083	28.6	1	7.8	<5	N.O	0
8	Kopila Kandel	5405665	3	4	25/02/2083	28.2	2	7.6	<5	N.O	0
9	Bodhdha Nath Gautam	54017671	3	12	25/02/2083	28.0	1	7.6	<5	N.O	0
10	Nilkanta Sharma Niure	54014351	3	10	25/02/2083	28.1	1	7.8	<5	N.O	0
11	Bin Maya Gurung	5408616	4	15	24/02/2083	30.4	1	7.8	<5	N.O	0
12	Prem Bahadur Chokhal	54020473	4	6	24/02/2083	30.5	1	7.8	<5	N.O	0
13	Basanta Sapkota	54025745	4	16N	24/02/2083	30.9	1	7.9	<5	N.O	0
14	Ward No.4 Wada Karyalya	54012999	4	20	24/02/2083	30.7	1	7.6	<5	N.O	0
15	Bishnu Kumar Kunwar	54028296	5	5	28/02/2083	28.3	1	8.0	<5	N.O	0
16	Rose Garden Public Bhawan	54019880	5	19	28/02/2083	28.3	1	8.0	<5	N.O	0
17	Hima Adhikari	54039097	5	5	28/02/2083	28.2	1	8.0	<5	N.O	0
18	Saroj Ghimire	54041248	5	25	28/02/2083	28.3	1	8.0	<5	N.O	0
19	War No 6 Ward Office	54037750	6	15	27/02/2083	31.0	1	8.0	<5	N.O	0
20	Sushree Mamata Sharma	54028888	6	1	24/02/2083	30.7	1	7.8	<5	N.O	0
21	Pashupati Adhikari	54037915	6	0	27/02/2083	30.5	1	7.9	<5	N.O	0
22	Jhabiswar Dhakal	5409606	7	16	24/02/2083	30.6	1	7.9	<5	N.O	0
23	Durga Bahadur Thapa Samet	54015405	7	3	24/02/2083	30.6	1	8.0	<5	N.O	0
24	Tribikram Thapa Chhetri	54015070	7	14.1	24/02/2083	30.8	1	8.0	<5	N.O	0
25	Chetana Village	54017018	7	16	24/02/2083	30.6	1	8.0	<5	N.O	0
26	Samodhi Shrestha	54025862	8	8	24/02/2083	30.5	1	8.1	<5	N.O	0
27	Harishchandra Ghimire	54011604	8	10	24/02/2083	30.6	1	7.9	<5	N.O	0
28	Sangita Poudel	54023006	8	16	24/02/2083	30.6	1	7.9	<5	N.O	0
29	Mahaendra Lal Shrestha	5409075	8	14	24/02/2083	30.5	1	8.0	<5	N.O	0
30	Buddhi Prasad Sapkota	5405571	9	13	24/02/2083	30.3	1	7.9	<5	N.O	0
31	Chandradevi Sapkota	54028400	9	19	24/02/2083	30.3	1	7.8	<5	N.O	0
32	Hema Lama Balampaki	54041442	9	21	24/02/2083	30.4	1	7.9	<5	N.O	0
33	Chandra Kumari Jarga	54033810	9	29	24/02/2083	30.1	1	7.9	<5	N.O	0
34	Goushuba Gurung	29277	10	18 B	19/02/2083	31.7	1	7.7	<5	N.O	0
35	Uddhav Bista	5401428/30	10	21B	19/02/2083	31.4	1	7.6	<5	N.O	25
	Repeated Sample				25/02/2083	28.0	1	7.8	<5	N.O	0
36	Netra Kala Bista	54016782	10	6	19/02/2083	32.3	1	7.6	<5	N.O	0

Executive Director

Prakash

Nepal Electricity Authority	54013247	10	26B	19/02/2083	31.7	1	7.6	<5	N O	575	<0.1	0
Bhuni Sara Bhurel	10993	10	3A	25/02/2083	28.4	1	7.7	<5	N O	564	<0.1	0
Jamuna Koirala	9763	11	8	19/02/2083	31.8	1	7.0	<5	N O	348	<0.1	0
Bha.Ma.Na.Pa.II Ward	54023213	11	12	25/02/2083	28.7	1	7.6	<5	N O	373	<0.1	0
Sumitra Rokka	54036707	11	18A	19/02/2083	32.1	1	7.9	<5	N O	267	<0.1	0
Narendra Gurung	54037251	11	25	25/02/2083	28.8	1	7.4	<5	N O	373	<0.1	0
Shalik Ram Poudel	12700690	12	21	19/02/2083	33.2	1	7.5	<5	N O	504	<0.1	0
Bimala Devi Neupane	54018238	12	4	19/02/2083	31.3	1	7.9	<5	N O	269	<0.1	0
Amudi Foods Pvt. Ltd.	54022667	12	4	19/02/2083	31.5	1	8.0	<5	N O	265	<0.1	0
Narayan Prasad Adhikari	54034542	12	23	19/02/2083	31.2	1	7.7	<5	N O	471	<0.1	0
Jayram Giri	54041314	13	1	27/02/2083	31.2	1	7.8	<5	N O	252	<0.1	0
Bir Bahadur Magar	54041226	13	1	27/02/2083	30.9	1	8.0	<5	N O	283	<0.1	0
Bhawana Pokhrel	54040583	13	1	27/02/2083	30.9	1	8.0	<5	N O	253	<0.1	0
Buddhiram Mahato	54040052	14	1	27/02/2083	30.9	1	8.0	<5	N O	262	<0.1	0
Netra Prasad Adhikari	54025582	14	1	27/02/2083	30.8	1	8.0	<5	N O	260	<0.1	0
Shambhu Mahato	54039115	14	1	28/02/2083	30.6	1	8.0	<5	N O	262	<0.1	0
Dhurbha Raj Poudel	54036968	15	IN	28/02/2083	28.4	1	7.7	<5	N O	241	<0.1	0
Binod Prasad Sharma	54032942	15	1	28/02/208	28.4	1	7.7	<5	N O	242	<0.1	0
Sabitri Kandel	54031959	15	10	28/02/208	28.3	1	8.0	<5	N O	300	<0.1	0
Bharatpur Mahanagarपालिका-16	54026293	16	1	28/02/208	28.4	1	7.8	<5	N O	322	<0.1	0
Chandra Prakash Paudel	54039375	16	1	28/02/208	28.1	1	8.0	<5	N O	300	<0.1	0
Nar Bahadur Gurung	54038247	16	0	28/02/208	28.4	1	7.7	<5	N O	391	<0.1	0
Ramali Mahato	54022975	22	1	27/02/2083	30.7	1	8.0	<5	N O	260	<0.1	0
Balram Poudel	54022968	22	1	27/02/2083	30.5	1	8.0	<5	N O	282	<0.1	0
Contaminated Water with Cowdung				19/02/2083								>50

* These values show lower and Upper Limits
Result: The tested samples have the parameters within the range as per the NDWQS 2079 for drinking water.



Approved By
Sanjay Baral
[Signature]
Executive Director

Checked By
Ram Krishna Khanal
[Signature]
Chemist