



Bharatpur Water Supply Management Board
Bharatpur, Chitwan
Drinking Water Quality Test Report of Randomly Selected Customers Ashadi 2083



Sl. No.	Name of Source			Date	Temp. (°C)	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Total Hardness mg/L	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID	Ward	Max. Concent. Limits, as per NDWQS-->									
1	Ramesh Kumar Karki	10281	1	30/03/2083	28.3	1	7.6	<5	N.O	674	234	<0.1	0
2	Purna Bahadur Shrestha	5401891	2	30/03/2083	28.2	1	6.6	<5	N.O	238	116	<0.1	0
3	Prakash Gurung	54011847	2	31/03/2083	29.3	1	7.5	<5	N.O	574	230	<0.1	0
4	Buddhi Bahadur Bhandari	5406164	2	30/03/2083	28.4	1	7.6	<5	N.O	518	180	<0.1	0
5	Ramakanta Sharma	623	2	30/03/2083	28.4	1	6.7	<5	N.O	239	90	<0.1	0
6	Radhika Krishna Shrestha	7925	2	30/03/2083	28.2	1	7.6	<5	N.O	511	194	<0.1	0
7	Satya Shal Seva Kendra, Narayanghat	32398	3	30/03/2083	28.5	1	7.6	<5	N.O	674	200	<0.1	0
8	Kopila Kandel	54036465	3	31/03/2083	28.9	1	7.6	<5	N.O	541	192	<0.1	0
9	Buddhi Nath Gautam	54017671	3	31/03/2083	28.8	1	7.6	<5	N.O	541	206	<0.1	0
10	Nilkantha Sharma Niure	54014351	3	31/03/2083	29.2	1	7.7	<5	N.O	539	198	<0.1	0
11	Bin Maya Gurung	5408616	4	21/03/2083	31.4	1	7.8	<5	N.O	453	178	<0.1	0
12	Pren Bahadur Chokhal	54020473	4	21/03/2083	31.3	1	7.9	<5	N.O	477	178	<0.1	0
13	Basanta Sapkota	54025745	4	21/03/2083	31.3	1	8.0	<5	N.O	479	184	<0.1	0
14	Ward No 4 Wada Karyalya	54012999	4	21/03/2083	31.4	1	7.7	<5	N.O	450	180	<0.1	0
15	Bishnu Kumar Kunwar	54028296	5	30/03/2083	29.1	1	8.0	<5	N.O	215	120	<0.1	0
16	Rose Garden Public Bhawan	54019880	5	30/03/2083	29.1	1	8.1	<5	N.O	214	130	<0.1	0
17	Hima Adhikari	54039097	5	30/03/2083	29.3	1	8.0	<5	N.O	312	140	<0.1	0
18	Saroj Ghimire	54041248	5	30/03/2083	29.4	1	8.0	<5	N.O	312	152	<0.1	0
19	War No 6 Ward Office	54037750	6	21/03/2083	31.0	1	8.0	<5	N.O	240	152	<0.1	0
20	Sushree Mamata Sharma	54028888	6	21/03/2083	31.3	1	7.8	<5	N.O	469	186	<0.1	0
21	Pashupati Adhikari	54037915	6	31/03/2083	30.7	1	8.0	<5	N.O	284	126	<0.1	0
22	Jhabswor Dhakal	5409606	7	21/03/2083	31.3	1	7.9	<5	N.O	436	170	<0.1	0
23	Durga Bahadur Thapa Samet	54015405	7	21/03/2083	31.3	1	7.9	<5	N.O	454	182	<0.1	0
24	Tribikram Thapa Chhetri	54015070	7	21/03/2083	31.3	1	7.8	<5	N.O	408	164	<0.1	0
25	Chetana Village	54017018	7	21/03/2083	31.4	1	7.9	<5	N.O	468	170	<0.1	0
26	Sanadlal Shrestha	54025862	8	21/03/2083	31.3	1	7.8	<5	N.O	451	170	<0.1	0
27	Harishchandra Ghimire	54011604	8	21/03/2083	31.4	1	7.9	<5	N.O	471	180	<0.1	0
28	Sangita Poudel	54023006	8	21/03/2083	31.2	1	7.8	<5	N.O	469	200	<0.1	0
29	Mahaendra Lal Shrestha	5409075	8	21/03/2083	31.2	1	7.8	<5	N.O	471	200	<0.1	0
30	Buddhi Prasad Sapkota	5405571	9	21/03/2083	31.2	1	7.8	<5	N.O	470	186	<0.1	0
31	Chandra devi Sapkota	54028400	9	21/03/2083	31.2	1	8.0	<5	N.O	346	190	<0.1	0
32	Hema Lama Balamapaki	54041442	9	21/03/2083	31.1	1	7.9	<5	N.O	470	194	<0.1	0
33	Chandra Kumari Jarga	54033810	9	21/03/2083	31.2	1	7.9	<5	N.O	469	194	<0.1	0
34	Goushba Gurung	29277	10	23/03/2083	31.9	1	7.7	<5	N.O	492	180	<0.1	0


Chemist

Executive Director

35	Uddhav Bista	5401428/30	10	21B	23/03/2083	31.5	1	7.5	<5	N.O	547	194	<0.1	0
36	Netra Kala Regmi	54016782	10	6	23/03/2083	32.1	1	7.6	<5	N.O	585	186	<0.1	0
37	Nepal Electricity Authority	54013247	10	26B	23/03/2083	32.1	1	7.7	<5	N.O	486	182	<0.1	0
38	Bhumi Sura Bhurtel	10093	10	3A	31/03/2083	29.0	1	7.6	<5	N.O	562	186	<0.1	0
39	Januna Koirala	9763	11	8	23/03/2083	31.1	1	7.8	<5	N.O	444	172	<0.1	0
40	Bha.Ma.Na.Pa.11 Ward	54033113	11	12	23/03/2083	28.4	1	7.7	<5	N.O	375	170	<0.1	0
41	Sumitra Rokka	54036707	11	18A	23/03/2083	28.4	1	8.1	<5	N.O	264	126	<0.1	0
42	Narendra Gurung	54037251	11	25	30/03/2083	28.4	1	7.4	<5	N.O	372 *	180	<0.1	0
43	Shalik Ram Poudel	12700/090	12	21	23/03/2083	32.2	1	7.6	<5	N.O	456 *	196	<0.1	0
44	Bimala Devi Neupane	54018238	12	4	23/03/2083	31.4	1	8.0	<5	N.O	270	140	<0.1	0
45	Amudi Foods Pvt. Ltd.	54022667	12	4	23/03/2083	31.3	1	8.1	<5	N.O	267	110	<0.1	0
46	Narayan Prasad Adhikari	54034542	12	23	23/03/2083	31.2	1	7.8	<5	N.O	451	170	<0.1	0
47	Jayram Giri	54041314	13	1	31/03/2083	31.0	1	8.0	<5	N.O	284	138	<0.1	0
48	Bir Bahadur Magar	54041226	13	1	31/03/2083	30.6	1	8.0	<5	N.O	261	146	<0.1	0
49	Bhawana Pokhrel	54040583	13	1	31/03/2083	30.7	1	8.0	<5	N.O	267	140	<0.1	0
50	Buddhiram Mahato	54040052	14	1	31/03/2083	29.9	1	8.1	<5	N.O	262	136	<0.1	0
51	Netra Prasad Adhikari	54025582	14	1	31/03/2083	29.8	1	8.1	<5	N.O	261	146	<0.1	0
52	Shambhu Mahato	54039115	14	1	31/03/2083	29.8	1	8.1	<5	N.O	261	146	<0.1	0
53	Dhruva Raj Poudel	54036968	15	1N	30/03/2083	29.3	1	7.6	<5	N.O	222	100	<0.1	0
54	Binod Prasad Sharma	54032942	15	1	30/03/2083	29.0	1	7.9	<5	N.O	311	142	<0.1	0
55	Sabirri Kandel	54031959	15	10	30/03/2083	29.0	1	8.0	<5	N.O	336	164	<0.1	0
56	Bharatpur Mahanagarpalika-16	54026293	16	1	30/03/2083	28.9	1	7.9	<5	N.O	336	154	<0.1	0
57	Chandra Prakash Paudel	54039375	16	1	30/03/2083	28.8	1	8.0	<5	N.O	336	182	<0.1	0
58	Nar Bahadur Gurung	54038247	16	0	30/03/2083	28.7	1	7.9	<5	N.O	335	184	<0.1	0
59	Ramila Mahato	54022975	22	1	31/03/2083	29.7	1	8.1	<5	N.O	261	146	<0.1	0
60	Balram Poudel	54022968	22	1	31/03/2083	29.7	1	8.1	<5	N.O	261	150	<0.1	0
61	Contaminated Water with Cowdung				21/03/2083									>50

* These values show lower and Upper Limits

Result: The tested samples have the parameters within the range as per the NDWQS 2079 for drinking water.



Approved By
Sanjay Baral
[Signature]
Executive Director

Checked By
Ram Krishna Khanal
[Signature]
Chemist