




Bharatpur Water Supply Management Board

Bharatpur, Chitwan


Drinking Water Quality Test Report of Randomly Selected Customers Shrawan 2083



S.N	Name of Source			Date	Temp. °C	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Total Hardness mg/L	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID	Ward	Zone	Max. Concent. Limits, as per NDVQS->	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	500	0.1-0.2	0
1	BMC Ward No- 1	54044059	1	18	26/04/2083	31.3	7.6	<5	NO	539	220	<0.1	0
2	Nimale Kumari Shrestha	54044602	1	16	26/04/2083	31.2	7.7	<5	NO	552	222	<0.1	0
3	Sher Bahadur Sunar	5402057	2	10	26/04/2083	31.2	7.7	<5	NO	512	216	<0.1	0
4	Satyra Shai Seta Kendra, Narayanghat	54032398	3	9	26/04/2083	31.1	7.5	<5	NO	645	238	<0.1	0
5	Suchitra Sapkota	54045436	2	21A	26/04/2083	31.8	7.8	<5	NO	441	176	<0.1	0
6	Lal Kumari Shival	5406584	2	12B	26/04/2083	32.1	6.6	<5	NO	240	92	<0.1	0
7	Bishnu Dawadi	5406785	2	5B	26/04/2083	29.6	6.6	<5	NO	235	100	<0.1	0
8	Sarmila Timisina	54044480	2	1	26/04/2083	31.5	7.8	<5	NO	440	174	<0.1	0
9	Rajendra Banjya	540288	3	2A	26/04/2083	31.2	7.6	<5	NO	534	197	<0.1	18
	Repeated Sample				29/04/2083								0
10	Athna Parlyar	54044062	3	12	26/04/2083	31.6	7.6	<5	NO	536	214	<0.1	0
11	Rabindra Kumar Kalawar	54014336	3	19	26/04/2083	30.4	7.7	<5	NO	532	213	<0.1	15
	Repeated Sample				29/04/2083								0
12	Dil Miya Dhakal	54038563	3	13	26/04/2083	30.5	7.5	<5	NO	564	228	<0.1	0
13	Srijana Koirala	54045316	4	22A	28/04/2083	30.5	7.9	<5	NO	339	174	<0.1	0
14	Manisha Shrestha	54045227	4	27	28/04/2083	30.3	7.5	<5	NO	484	187	<0.1	0
15	Khagaraj Sapkota	5409621	4	21N	28/04/2083	30.5	7.9	<5	NO	470	210	<0.1	0
16	Bramhakumari Rajjog Sewakendra	54043940	4	10	28/04/2083	30.2	7.9	<5	NO	339	190	<0.1	0
17	Kopila Adhikari	54035771	5	27	27/04/2083	29.9	7.8	<5	NO	456	154	<0.1	0
18	Bishnu Kumari Poudel	54032985	5	1N	27/04/2083	29.6	8.0	<5	NO	273	126	<0.1	0
19	War No 5 Ward Office	54035336	5	4	27/04/2083	29.5	8.0	<5	NO	217	107	<0.1	0
20	Abhyudaya Bahundehiya Sa. S. Lt	54016435	5	2	27/04/2083	29.1	7.8	<5	NO	398	180	<0.1	0
21	Chitnagar Oil Store	54039845	6	15	23/04/2083	29.8	7.8	<5	NO	245	120	<0.1	0
22	Anita Bajrakoti	54045076	6	0	23/04/2083	30.1	7.9	<5	NO	284	124	<0.1	>50
	Repeated Sample				28/04/2083								0
23	Puja Adhikari	54044692	6	3 ₃	23/04/2083	29.9	8.0	<5	NO	321	134	<0.1	0
24	Sarla Dhital	54015233	7	16	27/04/2083	29.7	7.7	<5	NO	433	186	<0.1	0
25	Ganu Tamang	54049928	7	6	27/04/2083	29.7	8.0	<5	NO	321	154	<0.1	0
26	Durga Devi Sharma	54044274	7	1	27/04/2083	29.5	8.1	<5	NO	320	146	<0.1	0
27	Nabraj Poudel	54042490	7	4	27/04/2083	29.6	7.9	<5	NO	472	214	<0.1	0
28	Hari Bahadur Chhetri	54043141	8	4	23/04/2083	30.0	8.0	<5	NO	322	140	<0.1	0
29	Krishna Hari Poudel	5402050	8	10	23/04/2083	29.9	7.7	<5	NO	406	170	<0.1	0
30	Kabita Gurung	54045414	8	8	23/04/2083	29.7	7.9	<5	NO	266	114	<0.1	0
31	Sunil Gurung	54044462	8	14	23/04/2083	29.1	7.8	<5	NO	422	190	<0.1	0

Chemist

Executive Director




32	Basudev Wagle	54028287	9	29	23/04/2083	29.6	1	7.8	<5	NO	428	110	<0.1	0
33	Bhishapat Kandel	54045300	9	22	23/04/2083	29.8	1	8.0	<5	NO	284	174	<0.1	0
34	Krishna Kumari Shrestha	54044221	9	21	23/04/2083	29.7	1	7.8	<5	NO	425	174	<0.1	0
35	Bharatpur Mahanagarika-10	54033346	10	26B	23/04/2083	27.5	1	7.0	<5	NO	483	196	<0.1	0
36	Chitwan Ma Bi	54033336	10	26	23/04/2083	27.5	2	7.5	<5	NO	584	240	<0.1	0
37	Ek Narayan Bhusal	54044861	10	8A	23/04/2083	28.2	1	7.4	<5	NO	766	290	<0.1	0
38	Bishnu Kandel	54010681	10	23B	23/04/2083	28.0	1	7.6	<5	NO	578	248	<0.1	0
40	Bha.Ma.Na.Pa.11 Ward	54043128	11	9	26/04/2083	30.7	1	7.7	<5	NO	411	190	<0.1	0
41	Sumitra Dhakal	54044884	11	24	23/04/2083	28.1	1	7.8	<5	NO	489	212	<0.1	0
	Rishiram Bhusal	54033618	11	3A	26/04/2083	31.9	1	7.5	<5	NO	367	170	<0.1	0
	Ishwori Poudel	54034491	11	8	26/04/2083	30.3	1	7.2	<5	NO	698	210	<0.1	0
43	Shakti Ram Poudel	54012690	12	21	26/04/2083	28.8	1	7.6	<5	NO	377	180	<0.1	3
	Repeated Sample				26/04/2083	29.8	1	7.8	<5	NO	515	210	<0.1	0
44	Bharatpur Ma.Na. Pa Ward No-12	54033210	12	5	25/04/2083	28.0	1	8.1	<5	NO	262	140	<0.1	0
45	Saskata Upreti Pandey	54045219	12	7	25/04/2083	27.9	1	7.9	<5	NO	261	120	<0.1	0
46	Narayan Prasad Adhikari	54034542	12	23	25/04/2083	28.4	1	7.7	<5	NO	457	185	<0.1	6
	Repeated Sample				26/04/2083	29.9	1	7.7	<5	NO	440	190	<0.1	0
47	Krishna Prasad Dhital	54043362	13	1	23/04/2083	29.9	1	8.0	<5	NO	284	140	<0.1	0
48	Khemraj Sharma	54037823	13	1	23/04/2083	29.9	1	8.0	<5	NO	283	130	<0.1	0
49	Sharmila Thapa Chaudhary	54044160	13	1	23/04/2083	29.8	1	8.1	<5	NO	282	120	<0.1	0
50	Prem Prasad Bhatta	54037209	14	1	23/04/2083	29.9	1	8.0	<5	NO	263	128	<0.1	0
51	Netra Prasad Adhikari	54025582	14	1	23/04/2083	29.8	1	8.0	<5	NO	263	130	<0.1	0
52	Umanath Poudel	54038945	14	1	23/04/2083	29.8	1	7.9	<5	NO	263	136	<0.1	0
53	Bharatpur Ma Na Pa Ward -15	54027812	15	1	28/04/2083	30.4	1	8.2	<5	NO	246	136	<0.1	0
54	Nirmala Pyakurel	54029879	15	1	28/04/2083	30.3	1	7.9	<5	NO	312	159	<0.1	>50
	Repeated Sample				29/04/2083	30.4	1	7.9	<5	NO	308	160	<0.1	0
55	Tej Prasad Tamang	54031493	15	10	28/04/2083	30.3	1	7.9	<5	NO	306	146	<0.1	0
56	Jeeban Bista	54043000	16	13	28/04/2083	30.2	1	7.9	<5	NO	338	180	<0.1	0
57	Prem Bahadur Adhikari	54041180	16	13	28/04/2083	30.1	1	7.8	<5	NO	320	140	<0.1	0
58	Digambar Kumar Pya	54035207	22	1	23/04/2083	29.8	1	8.0	<5	NO	263	124	<0.1	0
59	Minu Bote	54028383	22	1	23/04/2083	29.8	1	8.1	<5	NO			<0.1	0
60	Jahvor Bahadur Adhikari				23/04/2083									
61	Contaminated Water with Cowdung				23/04/2083									

* These values show lower and Upper Limits

Result: The tested samples have the parameters within the range as per the NDWOS 2079 for drinking water.

Checked By
Ram Krishna Kharel
Chemist



Approved By
Sanjay Baral
Executive Director