Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers Ashwin 2083

S.N	Name of Source				Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID	Ward	Zone	Max. Concent. Limits, as per NDWQS-->	^{0}C	5(10)	6.5 to 8.5*	5(15)	Non objectionable	1500	0.1-0.2	0
1	BMC Ward No- 1	54044059	1	18	22/06/2083	24.6	1	6.8	<5	N O	378	<0.1	0
2	Nirmala Kumari Shrestha	54044602	1	16	22/06/2083	24.5	1	7.7	<5	N O	584	<0.1	0
3	Sher Bahadur Sunar	5402057	2	10	22/06/2083	24.4	1	7.8	<5	N O	512	<0.1	0
4	Satya Shai Sewa Kendra, Narayanghat	54032398	3	9	22/06/2083	24.5	1	7.5	<5	N O	640	<0.1	0
5	Suchitra Sapkota	54045436	2	21A	22/06/2083	24.6	1	7.4	<5	N O	493	<0.1	0
6	Lal Kumari Silwal	5406584	2	12B	22/06/2083	24.6	1	6.7	<5	N O	234	<0.1	0
7	Shee Kanta Dhakal	54011468	2	20A	22/06/2083	24.8	1	7.8	<5	N O	435	<0.1	0
8	Sarmila Timsina	54044480	2	1	22/06/2083	25.0	1	8.0	<5	N O	435	<0.1	0
9	Rajendra Baniya	540288	3	2A	22/06/2083	25.2	1	7.7	<5	N O	542	<0.1	0
10	Atina Pariyar	54044062	3	12	23/06/2083	28.4	1	7.8	<5	N O	480	<0.1	0
11	Rabindra Kumar Kalawar	54014336	3	19	23/06/2083	27.7	1	7.7	<5	N O	572	<0.1	0
12	Dil Maya Dhakal	54038563	3	13	22/06/2083	28.7	1	7.5	<5	N O	423	<0.1	0
13	Srijana Koirala	54045316	4	22A	23/06/2083	27.1	1	7.9	<5	N O	333	<0.1	0
14	Manisha Shrestha	54045227	4	27	23/06/2083	27.3	1	7.6	<5	N O	488	<0.1	0
15	Khagaraj Sapkota	5409621	4	21N	23/06/2083	27.2	1	7.9	<5	N O	465	<0.1	0
16	Bramhakumari Rajyog SewaKendra	54043940	4	10	23/06/2083	27.2	1	8.0	<5	N O	334	<0.1	0
17	Kopila Adhikari	54035771	5	27	23/06/2083	27.6	1	8.0	<5	N O	283	<0.1	0
18	Bishnu Kumari Poudel	54032985	5	1N	23/06/2083	27.4	1	8.0	<5	N O	272	<0.1	0
19	War No 5 Ward Office	54035336	5	4	23/06/2083	27.7	1	7.9	<5	N O	294	<0.1	0
20	Abhyudaya Bahuuddeshiya Sa. S. Lt	54016435	5	2	23/06/2083	27.2	1	8.0	<5	N O	333	<0.1	0
21	Gitanagar Oil Store	54039845	6	15	18/06/2083	29.3	1	7.9	<5	N O	246	<0.1	0
22	Anita Bayalkoti	54045076	6	0	18/06/2083	29.6	1	8.1	<5	N O	324	<0.1	0
23	Puja Adhikari	54044692	6	3	18/06/2083	29.8	1	7.9	<5	N O	282	<01	0
24	Sarala Dhital	54015233	7	16	23/06/2083	27.5	1	7.8	<5	N O	465	<0.1	0
25	Gunu Tamang	54044928	7	6	23/06/2083	27.5	1	8.0	<5	N O	321	<0.1	0
26	Durga Devi Sharma	54044274	7	1	23/06/2083	27.5	1	8.0	<5	N O	321	<0.1	0
27	Nabraj Poudel	54042490	7	4	23/06/2083	27.2	1	7.6	<5	N O	501	<0.1	0
28	Hari Bahadur Chhetri	54043141	8	4	18/06/2083	29.6	1	8.1	<5	N O	260	<0.1	0
29	Krishna Hari Poudel	54022050	8	10	18/06/2083	29.5	1	8.0	<5	N O	338	<0.1	0
30	Kabita Gurung	54045414	8	8	18/06/2083	29.3	1	8.0	<5	N O	269	<0.1	0
31	Sunil Gurung	54044462	8	14	18/06/2083	29.1	1	8.0	<5	N O	325	<0.1	0
32	Basudev Wagle	54028287	9	29	18/06/2083	29.4	1	8.0	<5	N O	263	<0.1	0
33	Brihaspati Kandel	54045300	9	22	18/06/2083	29.7	1	7.8	<5	N O	437	<0.1	0
34	Krishna Kumari Shrestha	54044221	9	21	18/06/2083	29.3	1	7.9	<5	N O	438	<0.1	0
35	Bharatpur Mahanagarpalika-10	54013346	10	26B	22/06/2083	16.9	1	7.5	<5	N O	433	<0.1	0
36	Chitwan Ma.Bi	54013336	10	26	22/06/2083	16.0	1	7.7	<5	N O	508	<0.1	0

Chemist

Executive Director

37	Ek Narayan Bhusal	54044861	10	8A	22/06/2083	16.1	2	7.5	<5	NO	716	<0.1	0
38	Bishnu Kandel	54010681	10	23B	22/06/2083	18.5	2	7.7	<5	NO	517	<0.1	0
40	Bha.Ma.Na.Pa.11 Ward	54043128	11	9	23/06/2083	27.3	1	7.2	<5	NO	336	<0.1	>50
	Repeated Sample				24/06/2083								0
41	Sumitra Dhakal	54044884	11	24	22/06/2083	18.6	1	7.5	<5	NO	335	<0.1	0
	RishiRam Bhusal	54038618	11	3A	22/06/2083	18.3	1	7.8	<5	NO	332	<0.1	0
	Ishwori Poudel	54038491	11	8	22/06/2083	25.3	1	7.9	<5	NO	330	<0.1	0
43	Shalik Ram Poudel	54012690	12	21	22/06/2083	19.0	1	7.8	<5	NO	446	<0.1	0
44	Bharatpur Ma.Na. Pa Ward No-12	54033210	12	5	22/06/2083	18.9	1	8.1	<5	NO	248	<0.1	0
45	Sasikala Upreti Pandey	54045219	12	7	22/06/2083	19.6	1	8.0	<5	NO	258	<0.1	0
46	Narayan Prasad Adhikari	54034542	12	23	22/06/2083	20.3	1	7.8	<5	NO	451	<0.1	0
47	Krishna Prasad Dhital	54042362	13	1	18/06/2083	29.3	1	8.0	<5	NO	282	<0.1	0
48	Khemraj Sharma	54037823	13	1	18/06/2083	29.5	1	8.0	<5	NO	281	<0.1	0
49	Sharmila Thapa Chaudhary	54044160	13	1	18/06/2083	29.2	1	8.1	<5	NO	280	<0.1	0
50	Prem Prasad Bhatta	54037209	14	1	18/06/2083	29.3	1	8.1	<5	NO	258	<0.1	0
51	Netra Prasad Adhikari	54025582	14	1	18/06/2083	29.3	1	8.0	<5	NO	330	<0.1	0
52	Umanath Poudel	54038945	14	1	18/06/2083	29.3	1	8.1	<5	NO	246	<0.1	0
53	Bharatpur Ma Na Pa Ward -15	54027812	15	1	23/06/2083	27.2	1	8.2	<5	NO	243	<0.1	0
54	Nirmala Pyakurel	54029879	15	1	23/06/2083	26.9	1	8.0	<5	NO	304	<0.1	0
55	Tej Prasad Tamang	54031493	15	10	23/06/2083	27.0	1	8.0	<5	NO	310	<0.1	0
56	Inshan Bista	54042000	16	1	23/06/2083	27.1	1	7.9	<5	NO	304	<0.1	0
57	Prem Bahadur Adhikari	54043785	16	13	23/06/2083	26.9	1	8.0	<5	NO	306	<0.1	0
58	Digambar KumarPiya	54041180	16	13	23/06/2083	26.9	1	7.8	<5	NO	334	<0.1	0
59	Mina Bote	54035207	22	1	18/06/2083	29.1	1	8.0	<5	NO	245	<0.1	0
60	Ishwor Bahadur Adhikari	54028383	22	1	18/06/2083	28.9	1	8.1	<5	NO	258	<0.1	0
61	Contaminated Water with Cowdung				18/06/2083								>50

* These values show lower and Upper Limits

Result: The tested samples have the parameters within the range as per the NDWQS 2079 for drinking water.

Checked By
Ram Krishna Khanal
Chemist

Bharatpur Water Supply Management Board
Bharatpur, Chitwan-2064

Approved By
Sanjay Baral
Executive Director