Bharatpur Water Supply Management Board

Bharatpur, Chitwan

Drinking Water Quality Test Report of Randomly Selected Customers Kartik 2083

S.N	Name of Source				Date	Temp.	Turbidity (NTU)	pH	Colour (TCU)	Taste and Odor	Total Hardness (mg/L)	Electrical conductivity (µS/cm)	Residual Chlorine (mg/L)	Faecal Coliform (CFU/100ml)
	Customer Name	Customer ID	Ward	Zone	Max. Concent. Limits, as per NDWQS-->	^{0}C	5(10)	6.5 to 8.5*	5(15)	Non objectionable	500	1500	0.1-0.2	0
1	BMC Ward No- 1	54044059	1	18	20/07/2083	26.1	1	7.5	<5	NO	300	681	<0.1	0
2	Nirmala Kumari Shrestha	54044602	1	16	18/07/2083	25.7	1	7.6	<5	NO	254	654	<0.1	0
3	Sher Bahadur Sunar	5402057	2	10	18/07/2083	26.0	1	7.8	<5	NO	200	481	<0.1	0
4	Satya Shai Sewa Kendra, Narayanghat	54032398	3	9	20/07/2083	26.2	1	7.5	<5	NO	302	661	<0.1	0
5	Suchitra Sapkota	54045436	2	21A	18/07/2083	25.8	1	7.9	<5	NO	190	467	<0.1	0
6	Lal Kumari Silwal	5406584	2	12B	18/07/2083	25.7	1	6.6	<5	NO	114	281	<0.1	0
7	Shee Kanta Dhakal	54011468	2	20A	18/07/2083	26.1	1	7.8	<5	NO	196	459	<0.1	0
8	Sarmila Timsina	54044480	2	1	20/07/2083	26.2	1	8.0	<5	NO	240	460	<0.1	0
9	Rajendra Baniya	540288	3	2A	20/07/2083	26.1	1	7.7	<5	NO	240	533	<0.1	11
	Repeated Sample				21/07/2083									0
10	Atina Pariyar	54044062	3	12	20/07/2083	25.9	1	7.7	<5	NO	280	597	<0.1	0
11	Rabindra Kumar Kalawar	54014336	3	19	20/07/2083	25.8	1	7.7	<5	NO	246	535	<0.1	0
12	Dil Maya Dhakal	54038563	3	13	20/07/2083	25.5	1	7.7	<5	NO	254	532	<0.1	0
13	Srijana Koirala	54045316	4	22A	19/07/2083	26.1	1	7.8	<5	NO	180	337	<0.1	0
14	Manisha Shrestha	54045227	4	27	19/07/2083	26.1	1	7.7	<5	NO	210	476	<0.1	0
15	Khagaraj Sapkota	5409621	4	21N	19/07/2083	26.5	1	7.8	<5	NO	228	461	<0.1	0
16	Bramhakumari Rajyog SewaKendra	54043940	4	10	19/07/2083	26.5	1	8.0	<5	NO	176	332	<0.1	0
17	Kopila Adhikari	54035771	5	27	19/07/2083	26.4	1	7.9	<5	NO	166	284	<0.1	0
18	Bishnu Kumari Poudel	54032985	5	1N	19/07/2083	26.5	1	8.0	<5	NO	178	273	<0.1	0
19	War No 5 Ward Office	54035336	5	4	19/07/2083	26.4	1	8.1	<5	NO	120	211	<0.1	0
20	Abhyudaya Bahuuddeshiya Sa. S. Lt	54016435	5	2	19/07/2083	26.4	1	8.0	<5	NO	196	332	<0.1	0
21	Gitanagar Oil Store	54039845	6	15	15/07/2083	25.4	1	7.9	<5	NO	114	262	<0.1	0
22	Anita Bayalkoti	54045076	6	0	15/07/2083	25.8	1	8.0	<5	NO	130	257	<0.1	0
23	Puja Adhikari	54044692	6	3	15/07/2083	25.8	1	7.9	<5	NO	128	251	<01	0
24	Sarala Dhital	54015233	7	16	19/07/2083	26.4	1	7.7	<5	NO	220	440	<0.1	0
25	Gunu Tamang	54044928	7	6	19/07/2083	26.3	1	8.1	<5	NO	160	321	<0.1	0
26	Durga Devi Sharma	54044274	7	1	19/07/2083	26.5	1	8.1	<5	NO	164	322	<0.1	0
27	Nabraj Poudel	54042490	7	4	19/07/2083	26.1	1	7.7	<5	NO	228	477	<0.1	0
28	Hari Bahadur Chhetri	54043141	8	4	15/07/2083	25.9	1	8.1	<5	NO	148	320	<0.1	0
29	Krishna Hari Poudel	54022050	8	10	15/07/2083	25.9	1	8.0	<5	NO	140	322	<0.1	0
30	Kabita Gurung	54045414	8	8	15/07/2083	25.9	1	8.0	<5	NO	122	262	<0.1	0
31	Sunil Gurung	54044462	8	14	15/07/2083	26.0	1	8.0	<5	NO	168	344	<0.1	0
32	Basudev Wagle	54028287	9	29	15/07/2083	26.8	1	7.7	<5	NO	240	576	<0.1	0
33	Brihaspati Kandel	54045300	9	22	15/07/2083	26.4	1	7.8	<5	NO	210	476	<0.1	0
34	Krishna Kumari Shrestha	54044221	9	21	15/07/2083	26.2	1	7.7	<5	NO	190	449	<0.1	0
35	Bharatpur Mahanagarpalika-10	54013346	10	26B	18/07/2083	27.3	1	7.5	<5	NO	206	457	<0.1	0
36	Chitwan Ma Bi	54013336	10	26	18/07/2083	27.4	1	7.5	<5	NO	244	571	<0.1	0
37	Ek Narayan Bhusal	54044861	10	8A	18/07/2083	27.2	1	7.4	<5	NO	300	764	<0.1	0
38	Bishnu Kandel	54010681	10	23B	18/07/2083	27.0	1	7.6	<5	NO	240	573	<0.1	0

Chemist

Executive Director

40	**Bha.Ma.Na.Pa.11 Ward**	**54043128**	**11**	**9**	18/07/2083	26.2	1	7.8	<5	N O	230	469	<0.1	0
41	**Sumitra Dhakal**	**54044884**	**11**	**24**	7/2083	25.6	1	7.4	<5	N	160	348	<0.1	0
	RishiRam Bhusal	**54038618**	**11**	**3A**	18/07/2083	26.0	1	7.7	<5	NO	184	348	<0.1	0
	Ishwori Poudel	**54038491**	**11**	**8**	18/07/2083	26.3	1	7.8	<5	NO	224	471	<0.1	0
43	**Shalik Ram Poudel**	**54012690**	**12**	**21**	18/07/2083	26.7	1	7.7	<5	N O	224	457	<0.1	0
44	**Bharatpur Ma.Na. Pa Ward No-12**	**54033210**	**12**	**5**	18/07/2083	26.4	1	8.1	<5	N O	150	261	<0.1	0
45	**Sasikala Upreti Pandey**	**54045219**	**12**	**7**	18/07/2083	26.7	1	8.0	<5	N O	154	260	<0.1	0
46	**Narayan Prasad Adhikari**	**54034542**	**12**	**23**	18/07/2083	26.4	1	7.7	<5	N O	160	472	<0.1	0
47	**Krishna Prasad Dhital**	**54042362**	**13**	**1**	15/07/2083	25.9	1	8.2	<5	N O	130	256	<0.1	0
48	**Khemraj Sharma**	**54037823**	**13**	**1**	15/07/2083	25.6	1	8.1	<5	N O	140	320	<0.1	0
49	**Sharmila Thapa Chaudhary**	**54044160**	**13**	**1**	15/07/2083	25.3	1	7.9	<5	N O	140	292	<0.1	0
50	**Prem Prasad Bhatta**	**54037209**	**14**	**1**	15/07/2083	25.5	1	8.0	<5	N O	118	254	<0.1	0
51	**Netra Prasad Adhikari**	**54025582**	**14**	**1**	15/07/2083	25.4	1	8.1	<5	N O	148	277	<0.1	0
52	**Umanath Poudel**	**54038945**	**14**	**1**	15/07/2083	25.5	1	8.2	<5	N O	130	256	<0.1	0
53	**Bharatpur Ma Na Pa Ward -15**	**54027812**	**15**	**1**	19/07/2083	26.2	1	8.1	<5	N O	130	211	<0.1	0
54	**Nirmala Pyakurel**	**54029879**	**15**	**1**	19/07/2083	26.2	1	8.0	<5	N O	170	302	<0.1	0
55	**Tej Prasad Tamang**	**54031493**	**15**	**10**	19/07/2083	26.1	1	8.0	<5	N O	182	302	<0.1	0
56	**Inshan Bista**	**54042000**	**16**	**1**	19/07/2083	26.2	1	7.9	<5	N O	174	301	<0.1	0
57	**Prem Bahadur Adhikari**	**54043785**	**16**	**13**	19/07/2083	26.1	1	7.7	<5	N O	200	357	<0.1	0
58	**Digambar KumarPiya**	**54041180**	**16**	**13**	19/07/2083	26.2	1	7.7	<5	N O	220	358	<0.1	0
59	**Mina Bote**	**54035207**	**22**	**1**	15/07/2083	25.3	1	8.1	<5	N O	150	319	<0.1	0
60	**Ishwor Bahadur Adhikari**	**54028383**	**22**	**1**	15/07/2083	25.3	1	8.1	<5	N O	128	255	<0.1	0
61	Contaminated Water with Cowdung				15/07/2083									**>50**

* These values show lower and Upper Limits

Result: The tested samples have the parameters within the range as per the NDWQS 2079 for drinking water.

Checked By
Ram Krishna Khanal
Chemist

Bharatpur Water Supply Management Board
Bharatpur, Chitwan-2064

Approved By
Sanjay Baral
Executive Director